

VIRGINIA ELECTRIC AND POWER COMPANY


NORTH ANNA POWER STATION

MONTHLY OPERATING REPORT

MONTH February YEAR 81

(Revised)

APPROVED:



STATION MANAGER

8104210 563

OPERATING DATA REPORT

DOCKET NO. 50-338
DATE 04-06-81
COMPLETED BY L.L. Rogers
TELEPHONE (703) 894-5151 X2510

OPERATING STATUS

Notes

1. Unit Name: North Anna 1
2. Reporting Period: February 1981 (Revised)
3. Licensed Thermal Power (MWt): 2775
4. Nameplate Rating (Gross MWe): 947
5. Design Electrical Rating (Net MWe): 907
6. Maximum Dependable Capacity (Gross MWe): 898
7. Maximum Dependable Capacity (Net MWe): 850
8. If Changes Occur in Capacity Ratings (Items No. 3 thru 7) Since Last Report, Give Reasons:

N/A

9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	672	1,416	23,977
12. Number of Hours Reactor Was Critical	0	0	17,973.1
13. Reactor Reserve Shutdown Hours	0	0	213.1
14. Hours Generator On-Line	0	0	17,648.1
15. Unit Reserve Shutdown Hours	0	0	0
16. Gross Thermal Energy Generated (MWH)	0	0	44,832,142
17. Gross Electrical Energy Generated (MWH)	0	0	14,316,912
18. Net Electrical Energy Generated (MWH)	0	0	13,485,003
19. Unit Service Factor	0	0	73.6
20. Unit Availability Factor	0	0	73.6
21. Unit Capacity Factor (Using MDC Net)	0	0	66.2
22. Unit Capacity Factor (Using DER Net)	0	0	62.0
23. Unit Forced Outage Rate	0	0	5.9
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):			

N/A

25. If Shut Down At End Of Report Period, Estimated Date of Startup: March 17, 1981
26. Units In Test Status (Prior to Commercial Operation):

Forecast Achieved

INITIAL CRITICALITY
INITIAL ELECTRICITY
COMMERCIAL OPERATION

