



THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

ILLUMINATING BLDG. • PUBLIC SQUARE • CLEVELAND, OHIO 44101 • TELEPHONE (216) 623-1350 • MAIL ADDRESS: P. O. BOX 5000

Serving The Best Location in the Nation

Dalwyn R. Davidson
VICE PRESIDENT
SYSTEM ENGINEERING AND CONSTRUCTION



May 4, 1981

Mr. Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Perry Nuclear Power Plant
Docket Nos. 50-440; 50-441
Emergency Procedures and Training
for Station Blackout Events

Dear Mr. Eisenhut:

In response to your Generic Letter 81-04, dated February 25, 1981, we submit the following information concerning station blackout events at the Perry Plant.

1. An event specific procedure which addresses a station blackout event will be developed prior to initial cold licensing. This procedure will, as a minimum, provide guidance for the concerns identified in your letter.
2. We are actively participating in the General Electric BWR Owners Group efforts to develop symptom oriented emergency procedures. These procedures when drafted, will provide the correct guidance for assuring adequate core cooling and containment integrity for the station blackout event. The utilization of these emergency procedures, if required by plant conditions, will be concomitant with the event specific procedure for the station blackout event previously described. The emergency procedures will also be developed prior to initial cold licensing.

Boo'
s
1/0

8105120252


F

Mr. Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation
Page 2

3. Training in the use of the emergency procedures, as well as the specific station blackout procedure will be conducted on the Perry simulator prior to initial cold licensing.

If you require further information, please let me know.

Very truly yours,



Dalwyn R. Davidson, Vice President
System Engineering and Construction

DRD:dlp

cc: G. Charnoff, Esq.
D. H. Hauser, Esq.
J. Hughes, NRC Resident Inspector
Nuclear Regulatory Commission
Document Management Branch
Washington, D. C. 20555

Dalwyn R. Davidson who, being duly sworn, deposed and said that (1) he is Vice President, System Engineering and Construction of The Cleveland Electric Illuminating Company, (2) he is duly authorized to execute and file this report on behalf of The Cleveland Electric Illuminating Company and as duly authorized agent for Duquesne Light Company, Ohio Edison Company, Pennsylvania Power Company and the Toledo Edison Company, and (3) the statements set forth therein are true and correct to the best of his knowledge, information and belief.

Dalwyn R. Davidson
Dalwyn R. Davidson

Sworn to and subscribed before me, this 5th day of May, 1981.

William J. Kerner

WILLIAM J. KERNER, Attorney
NOTARY PUBLIC - STATE OF OHIO
My commission has no expiration date.
Section 147.03 R.C.