

THE CINCINNATI GAS & ELECTRIC COMPANY



May 6, 1981
QA-1423

E. A. BORGMANN
SENIOR VICE PRESIDENT



U. S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Attention: Mr. G. Fiorelli, Chief
Reactor Construction & Engineering
Support Branch

RE: WM. H. ZIMMER NUCLEAR POWER STATION - UNIT I
10CFR50.55(e) E-14, GENERAL ELECTRIC CO. SUPPLIED
IN-CORE POWER RANGE SENSOR - ELECTRICAL PLUG
CONNECTOR, CONSTRUCTION PERMIT CPPR 88, DOCKET
NO. 50-358, W. O. 57300-957, JOB E-5590

Gentlemen:

On April 6, 1981, the NRC Site Senior Resident Inspector was notified by phone of a possible 10CFR50.55(e) condition regarding environmental discrepancies between the Wm. H. Zimmer NPS FSAR, Page 7.6-54, Para. 7.6.1.9.5.2 and G. E. Co. Standard Catalogue information for the LPRM In-Core Power Range Sensor Electrical Connector, Cat. No. X901-200.

Cincinnati Gas and Electric Co. is continuing to investigate this situation. A report will be submitted within sixty (60) days.

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By

E. A. BORGMANN
SENIOR VICE PRESIDENT

DJS:ec

cc: NRC Resident Inspector
Attn: F. T. Daniels
NRC Office of Inspection & Enforcement
Washington, D. C. 20555

8105120 331

S

13019
5/10