

TEXAS UTILITIES SERVICES INC.

2001 BRYAN TOWER · DALLAS, TEXAS 75201

Log # TXX-3360
File # 909.4

July 1, 1981

Mr. Spottswood Burwell

Mr. Spottswood Burwell
Licensing Project Manager
U. S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D.C. 20555



SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
POST-LOCA OPERATION OF EXHAUST DAMPER
FOR ESF FILTER TRAIN IN THE SAFEGUARDS BUILDING

REF: LETTER TXX-3315; DAMPERS FOR ESF FILTER TRAIN IN
SAFEGUARDS BUILDING; JUNE 19, 1981

Dear Mr. Burwell:

As discussed in the referenced letter, the exhaust dampers in the Safeguards Building ESF filter trains are manually operable. We are evaluating Post-Loca radiation levels in the Auxiliary Building (the damper locations) to assure accessibility. In the event our evaluation indicates potential hazard (hence inaccessability) for personnel we will lock-open the dampers.

If you have any questions, please call.

Sincerely,

H. C. Schmidt for

H. C. Schmidt

AND:tl's

cc: R. D. Calder
R. E. Ballard
J. C. Kuykendall
R. A. Jones

*Boo1
Silo*

8107070450 810701
PDR ADOCK 05000445
H PDR