

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N J S G S 2 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
0 1 REPORT SOURCE L 6 0 5 0 0 0 3 1 1 7 0 6 0 3 8 1 8 0 6 3 0 3 1 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 At 0440 hours, on June 3, 1981, a high level in No. 22 Steam Generator resulted in
0 3 a Turbine Trip, Reactor Trip and Safety Injection, Boron Injection Tank concentration
0 4 decreased to less than 20,000 ppm of boron and Action Statement 3.5.4.1 was entered.
0 5 This occurrence constituted operation in a degraded mode IAW Technical Specification
0 6 6.9.1.9.b. Previous similar occurrence: 81-09.
0 7
0 8

0 9 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE
S F 11 X 12 Z 13 Z Z Z Z Z Z 14 Z 15 Z 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20
17 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
8 1 0 3 2 0 3 L 0
21 22 23 24 25 26 27 28 29 30 31 32
ACTIONS TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
Z 18 Z 19 Z 20 Z 21 0 0 0 0 Y 23 N 24 Z 25 Z 9 9 9 9 26
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The Safety Injection caused dilution of the Boron Injection Tank. The Tank was
1 1 borated until concentration was within the allowable limits. At 2229 hours, on
1 2 June 3, 1981, the Action Statement was terminated.
1 3
1 4

1 5 FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)
E 28 0 2 0 29 N/A A 31 Operator Observation
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
1 6 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
Z 33 Z 34 NA NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
1 7 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
0 0 0 37 Z 38 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
1 8 PERSONNEL INJURIES NUMBER DESCRIPTION (41)
0 0 0 40 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
1 9 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43)
Z 42 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
2 0 PUBLICITY ISSUED DESCRIPTION (45)
N 44 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

NRC USE ONLY

8107130247 B10630
PDR ADOCK 05000311
S PDR

J. J. Espey

PHONE 609-935-0998