

CONTROL BLOCK:

						1
--	--	--	--	--	--	---

 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
7	8

REPORT SOURCE

L	6	0	5	0	0	0	3	1	8	7	0	6	0	4	8	1	8	0	7	0	3	8	1	9
60	61	DOCKET NUMBER						68	69	EVENT DATE						74	75	REPORT DATE						80

0 2 | At 1430 during normal operation while performing a surveillance test, it

0 3 | was discovered that temperature transmitter 122HB, which inputs to RPS

0 4 | Channel "B" Delta T power calculator was out of tolerance in a non conser-

0 5 | vative direction (T.S. 3.3.1.1). All trip units that receive input from

0 6 | Delta T power were bypassed to replace the transmitter. RPS Channel "B"

0 7 | was returned to normal at 1500. The three redundant RPS channels re-

0 8 | mained operable. Similar events: 81-25 and 05000317/81-32.

SYSTEM CODE I A (11)		CAUSE CODE E (12)		CAUSE SUBCODE G (13)		COMPONENT CODE I N S T R U (14)		COMP. SUBCODE T (15)		VALVE SUBCODE Z (16)	
LER/RO REPORT NUMBER 17		EVENT YEAR 8 1 (21 22)		SEQUENTIAL REPORT NO. 0 3 0 (24 25 26)		OCCURRENCE CODE 0 3 (28 29)		REPORT TYPE L (30)		REVISION NO. 0 (32)	
ACTION TAKEN C (18)		FUTURE ACTION X (19)		EFFECT ON PLANT Z (20)		SHUTDOWN METHOD Z (21)		HOURS 0 0 0 0 (22 23 24 25)		ATTACHMENT SUBMITTED N (23)	
NPRD-4 FORM SUB. Y (24)		PRIME COMP. SUPPLIER L (25)		COMPONENT MANUFACTURER R 3 3 5 (26 27 28 29)							

1 0 The cause of failure is unknown but apparently similar to failures re-

1 1 ported under the LER's referenced above. The transmitter was replaced

1 2 with a spare. Bench testing of failed instruments and consultation with

1 3 the manufacturer has continued since issue of LER 81-15. An updated re-

1 4 port will be submitted when the failure cause is identified.

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

1 5 E 28 1 0 0 29 NA B 31 Routine Test 32

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 Z (33) 10 (34) NA

7 8 9 11

AMOUNT OF ACTIVITY (35)

LOCATION OF RELEASE (36)

NA

45 80

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	37	Z	38	NA	

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	NA

LOSS OF OR DAMAGE TO FACILITY					
TYPE		DESCRIPTION			
1	9	Z	(43)	NA	
7	8	9	10	8107130265 810703	

2		0		N		44		NA		PDR ADOCK 05000318		PDR		NRC USE ONLY	
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22