

CONTROL BLOCK: 

--	--	--	--	--	--

 (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	Y	J	A	F	1	2	0	0	-	0	0	0	0	-	0	0	0	3	4	1	1	1	1	4		5					
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35					
LICENSE CODE								LICENSE NUMBER																	LICENSE TYPE							CAT	

CON'T

REPORT SOURCE 0 1 7 8 L 6 0 5 0 0 0 3 3 3 7 0 6 0 1 8 1 2 0 6 3 0 8 1 9  
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During normal operation, while conducting surveillance, switch 3 on reactor water  
0 3 | level instrument 02-3-LIS-58A (used for recirculation pump trip) did not function.  
0 4 | Repeated retests could not duplicate the failure. Surveillance was increased to  
0 5 | daily and on June 2, 1981 the switch failed again. Redundant instruments (LIS-  
0 6 | 57A, 57B and 58B) were operable. No significant hazard existed.  
0 7 |  
0 8 |

09		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE						COMP. SUBCODE		VALVE SUBCODE	
7	8	C	B	E		F		I	N	S	T	R	U	S		Z	
		9	10	11	12	13	14	15	16	17	18	19	20				
(17) LER NO. REPORT NUMBER		EVENT YEAR				SEQUENTIAL REPORT NO.				OCCURRENCE CODE		REPORT TYPE		REVISION NO.			
81		81		—		045		/		03		L		0			
21		22		23		24		25		26		27		28			
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER			
A	Z	Z		Z						N		Y	N				
29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44		
								0000						Y010			
								40						47			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | Failure of the magnetic switch is believed to be due to age. Replacement of the

1 1 | switch and calibration following the failure on 6/2/81, restored the instrument

1 2 | to a fully operable status. No additional action is required.

1 3 |

1 4 |

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	E	28	1	0	0	29	NA	44
7	8	9	10	11	12	13	14	15	16
ACTIVITY		CONTENT		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
1	6	Z	33	7	34	NA	44	45	46
7	8	9	10	11	12	13	14	15	16
PERSONNEL EXPOSURES		TYPE		DESCRIPTION					
1	7	0	0	0	37	Z	38	NA	44
7	8	9	10	11	12	13	14	15	16
PERSONNEL INJURIES		DESCRIPTION							
1	8	0	0	0	40	NA	44	45	46
7	8	9	10	11	12	13	14	15	16
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION					
1	9	Z	42	NA	44	45	46	47	48
7	8	9	10	11	12	13	14	15	16
PUBLICITY		ISSUED		DESCRIPTION					
2	0	N	44	NA	44	45	46	47	48
7	8	9	10	11	12	13	14	15	16