

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--	--	--

 (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CCT

REPORT

REPORT SOURCE L 0 5 0 0 0 3 3 4 7 0 6 0 1 8 1 3 0 7 0 1 8 1 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

2 | 2 | At 0400 hours on 6/1/81 with reactor power at 100%, the Train A Chemical Addition

2 | 3 | Tank level transmitter [LT-QS-101A] failed low making this train inoperable for

2 | 4 | chemical addition to the Quench Spray System. At 0420 hours, for unknown reasons,

2 | 5 | the channel returned to normal before failing low for the second time at 0651

2 | 6 | hours. Power operation continued as per Technical Specification 3.6.2.3. There

2 | 7 | were no safety implications since the Train B components remained operational

2 | 8 | throughout the incident.

7 8 9		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE	
3 9		S A 11		X 12		Z 13		I N S T R U 14				T 15		Z 16	
7 8		9 10		11		12		13 14 15 16 17				18 19		20	
17		EVENT YEAR				SEQUENTIAL REPORT NO.		OCCURRENCE CODE				REPORT TYPE		REVISION NO.	
18		8 1		23		0 5 6		0 3				L		10	
21		22		23		24 25 26		27 28 29				30		31	
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS				ATTACHMENT SUBMITTED		PRIME COMP. SUPPLIER	
X 18		X 19		Z 20		Z 21		0 0 0 0				Y 22		N 23	
23		24		25		26		37 38 39 40				41		42	
43		44		45		46		47				48		49	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 The cause is unknown. A surveillance procedure was performed on 6/1/81 to
2 troubleshoot the loop. No problems were found. At 1120 hours on 6/1/81, the
3 channel was returned to service. The instrumentation department will monitor the
4 operation of this instrument in an attempt to determine the cause for the
5 intermittent failures.

FACILITY STATUS (E) (30) POWER 1 0 0 (30) OTHER STATUS N/A (30) METHOD OF DISCOVERY A (31) DISCOVERY DESCRIPTION Control Room Annunciator (32)

ACTIVITY CONTENT (35) LOCATION OF RELEASE (36)
 RELEASED OF RELEASE AMOUNT OF ACTIVITY
 1 2 3 4 N/A 45 N/A 46

DATE		TIME		LOCATION		DESCRIPTION	
1	2	3	4	5	6	7	8
							N/A

0 0 0 4 N/A

N/A

NRC USE ONLY

NBC USE ONLY

B107130305 B10702
PDR ADDCK 05000334
S PDR

S. S. Lacey

PHONE 412-643-8525

Attachment to LER 81-056/03L
Beaver Valley Power Station
Duquesne Light Company
Docket No. 50-334

No further information is available or needed to satisfy the reporting requirement.