

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--

 (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	Y	J	A	F	1	2	0	0	-	0	0	0	0	-	0	0	0	3	4	1	1	1	1	4			5
7	8	14						15	25										26	30					57	CAT	58		
		LICENSEE CODE							LICENSE NUMBER											LICENSE TYPE									

CONT

0	1
7	8

REPORT SOURCE

L	6	0	5	0	0	0	3	3	3	7	0	6	0	8	8	1	3	0	7	0	2	8	1	9
60	61	DOCKET NUMBER						68	69	EVENT DATE						74	75	REPORT DATE						80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During normal operation, while conducting surveillance required by TS Table 4.2-6,

0 3 | torus water temperature transmitter 27-TT-101D was found out of calibration by 1.6

0 4 | percent. Redundant transmitters 101A, 101B and 101C were within calibration. No

0 5 | significant hazard existed.

06 _____

0	7	
---	---	--

08 _____ 80

7 8

SYSTEM CODE
9 10

CAUSE CODE
11

CAUSE SUBCODE
12

COMPONENT CODE
13 14 15 16 17 18

COMP SUBCODE
19

VALVE SUBCODE
20

(17)	LER RO REPORT NUMBER	[<u>E</u>][<u>V</u>] 21 22	[<u>-</u>] 23	SEQUENTIAL REPORT NO.	[<u>0</u>][<u>5</u>][<u>0</u>] 24 25 26	[<u>/</u>] 27	OCCURRENCE CODE	[<u>0</u>][<u>3</u>] 28 29	REPORT TYPE	[<u>L</u>] 30	[<u>-</u>] 31	REVISION NO.	[<u>0</u>] 32
ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP SUPPLIER	COMPONENT MANUFACTURER					
[<u>E</u>](18)	[<u>Z</u>](19)	[<u>Z</u>](20)	[<u>Z</u>](21)	[<u>0</u>][<u>0</u>][<u>0</u>] 37 38 39	[<u>N</u>](23)	[<u>N</u>](24)	[<u>L</u>](25)	[<u>T</u>][<u>0</u>][<u>4</u>][<u>0</u>] 44 45 46 47					

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10	Calibration of 27-TT-101D corrected the instrument drift and restored the instrument to
11	a fully operable status within 4 hours. No additional action is required.

1	2	
---	---	--

1	3	
---	---	--

1	4	
---	---	--

1 5 FACILITY STATUS E 28 % POWER 1 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Surveillance 32

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 2 3 33 4 34 10 11

AMOUNT OF ACTIVITY (35)

NA

44

LOCATION OF RELEASE (36)

NA

45 80

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	NA	(39)

		PERSONNEL INJURIES			
NUMBER		DESCRIPTION			
1	2	0	0	0	40 NA

1 9 Z (42) NA

8 9 10
PUBLICATION
ISSUED DESCRIPTION (45) NA S PDR
2 0 N (44) 8107130405 810702
PDR ADOCK 05000333
PDR
NRC USE ONLY
68 69 70

NRC USE ONLY

68 69