

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
7	8

REPORT SOURCE

L	6	0	5	0	0	0	3	1	8	7	0	6	0	2	8	1	8	0	7	0	2	8	1	9
60	61	DOCKET NUMBER						68	69	EVENT DATE						74	75	REPORT DATE						80

0 2 | At 1800 during surveillance testing, #23 HPSI Pump failed to start on a

0 3 | SIAS "B-2", but pump did start satisfactorily from the Control Room

0 4 | (T.S. 3.5.2a). #21 HPSI Pump remained operable during this event. A

0 5 | relay was replaced, #23 HPSI Pump was tested and returned to service at

0 6 | 0030 on 06-03-81. No similar events have been reported.

7 8 9 10 11 12 13 14 15 16 17 18 19 20

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE

U 9 E B 11 E 12 A 13 R E L A Y X 14 H 15 Z 16

(17) LER/RO REPORT NUMBER 81 —

EVENT YEAR 027 /

SEQUENTIAL REPORT NO. 03

OCCURRENCE CODE L —

REPORT TYPE 0

REVISION NO.

ACTION TAKEN (C) 18 FUTURE ACTION (Z) 19 EFFECT ON PLANT (Z) 20 SHUTDOWN METHOD (Z) 21 HOURS (0000) 22 ATTACHMENT SUBMITTED (N) 23 NPRD-4 FORM SUB. (Y) 24 PRIME CC.WP. SUPPLIER (A) 25 COMPONENT MANUFACTURER (A109) 26

1 0 | #23 HPSI Pump Motor Breaker would not close due to the failure of con-
1 1 | trol time delay relay 2/SB2 (Agastat #7012PB). The relay's normally open
1 2 | contact would not close, and it was replaced with a like spare. Because
1 3 | this has not been a repetitive event, no preventive action is deemed
1 4 | necessary.

7 8 9

FACILITY STATUS (1) 5 (E) (28) % POWER (1) 0 0 (29) OTHER STATUS (30) NA METHOD OF DISCOVERY (B) (31) DISCOVERY DESCRIPTION (32) Surveillance Testing

80

ACTIVITY CONTENT
RELEASED Gr RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 6 Z 33 Z 34 NA NA

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0					
			(37) Z	(38) NA					

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
1	8	0	0
0	0	0	40
		NA	

1	9	Z	(42)	NA
---	---	---	------	----

7 8 9 10
PUBLICITY
ISSUED DESCRIPTION (45)
2 3 L N (44) NA
7 8 9 10
8107130477 810702
PDR ADOCK 05000318
S FDR
NRC USE ONLY
58 59 60

NAME OF PREPARER

M. A. Junge/P. G. Rizzo

PHONE

(301) 269-4747/4786