



**Consumers
Power
Company**

James W Cook
Vice President - Projects, Engineering
and Construction

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0453

80-08 #3

June 30, 1981

Mr J G Keppler, Regional Director
Office of Inspection & Enforcement
US Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137



MIDLAND PROJECT
DOCKET NOS 50-329, 50-330
ECCAS CABINET WIRING
FILE: 0.4.9.45 UFI: 73*10*01, 02210(S), 39301(E) SERIAL: 12036

References: J W Cook letters to J G Keppler, Same Subject:

- (1) Serial 10087, dated December 17, 1980
- (2) Serial 11502, dated February 27, 1981

This letter, as were the referenced letters, is an interim report on the ECCAS cabinet wiring.

Babcock & Wilcox stated in the last interim report that Bailey Controls Company shall initiate field changes and/or drawing revisions as necessary to bring the Midland ECCAS drawings and hardware into agreement.

B&W has submitted these field changes entitled "Correction of ECCAS Wiring Errors" for review and implementation. CPCo is presently reviewing the field changes and upon their approval will issue them to Bechtel for implementation.

Completion of the corrective action remains estimated to be September 30, 1981.

Another report, either interim or final, will be sent on or before October 15, 1981.

James W. Cook

MJS/lr

IE27
51/0

JUL 2 1981

8107140085 810630
PDR ADOCK 05000329
S PDR

CC: Director of Office of Inspection & Enforcement
Att Mr Victor Stello, USNRC (15)

Director, Office of Management
Information & Program Control, USNRC (1)

RJCook, USNRC Resident Inspector
Midland Nuclear Plant (1)

CBechhoefer, ASLB Panel
RSDecker, ASLB Panel
FPCowan, ASLB Panel
AN&L Appeal Panel
MMCherry, Esq
MSinclair
BStamiris
CRStephens, USNRC
WDPaton, Esq, USNRC
FJKelly, Esq, Attorney General
SHFreeman, Esq, Asst Attorney Gen
GTTaylor, Esq, Asst Attorney Gen
WHMarshall
GJMerritt, Esq, TNK&J