

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--	--

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	I	D	C	C	2	0	0	-	0	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5
7	8						14	15											25	26							57	CAT	58
LICENSEE CODE		LICENSE NUMBER																LICENSE TYPE											

CON'T

REPORT SOURCE: 0 1 7 8 L 6 0 5 0 0 0 3 1 6 7 0 6 0 4 8 1 8 0 7 0 3 8 1 9
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | DURING A SURVEILLANCE TEST, BIT ISOLATION VALVE, ICM-250 FAILED TO OPEN FROM
0 3 | CONTROL ROOM. THIS CONSTITUTED AN INOPERABLE FLOW PATH REQUIRED BY T.S.
0 4 | 3.5.2. VALVE OPENED MANUALLY AND CLOSED IN NORMAL MANNER FROM CONTROL ROOM.
0 5 | THE ACTION REQUIREMENTS WERE MET. THE VALVE WAS OUT OF SERVICE FOR 2 HOURS.
0 6 | THE REDUNDANT FLOW PATH REMAINED OPERABLE. HEALTH AND SAFETY OF THE PUBLIC
0 7 | WERE NOT AFFECTED.
0 8 |

09		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE			
0	9	S	F	X		Z		V	A	L	V	O	P	B		Z	
7	8	9	10	11	12	12	13	13	14	15	16	17	18	19	20		
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.							
17		8	1	—		0	2	5	/	0	3	L		—		0	
21	22	23	24	25	26	27	28	29	30	31	32						
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
E		Z		Z		Z		0	0	0	0	N		N		A	
18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 IT APPEARS THE EVENT WAS CAUSED BY TOO LOW A SETTING ON THE "OPEN" TORQUE

1 1 SWITCH. THE LIMITORQUE CUT OUT BEFORE OVERCOMING THE POSITIVE SEATING

1 2 OF THE DOUBLE PARALLEL DISC GATE VALVE. THE TORQUE SWITCH SETTING WAS

1 3 INCREASED.

1 4

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	E	28	1	0	0	29	N/A	B
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
1	6	Z	33	Z	34	N/A	35	N/A	36
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION			
1	7	0	0	0	37	Z	38	N/A	39
PERSONNEL INJURIES		NUMBER		DESCRIPTION					
1	8	0	0	0	40	N/A	41		
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION					
1	9	Z	42	N/A	43				
PUBLICITY		ISSUED		DESCRIPTION					
2	0	1	44	N/A	45				

NRC USE ONLY

8107140385 810703
PDR ADCK 05000316
S PDR

BERT H. PIEHL

PHONE 616-465-5901, EXT. 1036

6
7
8
9
10
11
12