

rm

Southern California Edison Company

P. O. BOX 800
2244 WALNUT GROVE AVENUE
ROSEMEAD, CALIFORNIA 91770

L. T. PAPAY
VICE PRESIDENT



July 1, 1981

Mr. R. H. Engelken, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Region V
Suite 202, Walnut Creek Plaza
1990 North California Boulevard
Walnut Creek, California 94596



Dear Mr. Engelken:


Subject: Docket Nos. 50-361 and 50-362
San Onofre Nuclear Generating Station, Units 2 and 3

By letter to your office dated May 18, 1981 we transmitted a final report in accordance with 10CFR50.55(e) regarding noncompliance with ASME Code NCA-3867.4a on chemical analysis verification of material used for manufacture of ASME Code bolts with nominal diameter exceeding one inch. That report stated that ASME Code Case N242 would be invoked by the Project for these bolts.

The purpose of this letter is to advise you that Code Case N-310, which deals specifically with bolting materials and which was confirmed by publication June, 1981, will be invoked instead of Code Case N-242.

If you have any questions regarding this supplement to the report, we would be pleased to discuss them with you at your convenience.

Very truly yours,


for L. T. Papay

cc: Victor Stello (NRC, Director I&E)
R. J. Pate (NRC, San Onofre, Units 2 and 3)

IE21
5/10