

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

7 8 9 14 15 25 26 30 37 38 56 57 58

0 1 I A D A C 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 5

LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT

CON'T

0	1
---	---

REPORT SOURCE

L	5	0	5	0	0	0	3	3	1	7	0	6	0	2	8	1	3	0	7	0	1	8	1	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

60 61 DOCKET NUMBER 64 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During reactor startup Suppression Chamber to Drywell Vacuum Breaker

0 3 | Valve, CV 4327H, did not close after Torus inerting. Reactor taken to

0 4 | cold shutdown complying with Tech Spec 3.7.A.4. Maintenance action co

0 5 | mpleted within 18 hours. No previous occurrences of this type have be

0 6 | en r. ported.

0 7 |

0 8 |

SYSTEM CODE [0] [3] 7 8		CAUSE CODE [S] [A] (11) 9 10		CAUSE SUBCODE [E] (12) 11		COMPONENT CODE [B] [13] [V] [A] [L] [V] [O] [P] (14) 12 13 14 15 16 17 18						COMP SUBCODE [D] (15) 19		VALVE SUBCODE [Z] (16) 20	
(17) LER/RO REPORT NUMBER [8] [1] 21 22		EVENT YEAR [] 23		SEQUENTIAL REPORT NO. [0] [2] [1] 24 25 26		OCCURRENCE CODE [] 27		REPORT TYPE [0] [3] 28 29		REPORT TYPE [L] 30		REVISION NO. [] 32			
ACTION TAKEN [B] (18) [Z] (19) 33 34		FUTURE ACTION [] 35		EFFECT ON PLANT [A] (20) 36		SHUTDOWN METHOD [A] (21) 37		HOURS (22) [0] [0] [1] [8] 38 39 40 41		ATTACHMENT SUBMITTED [N] (23) 42		NPRO-4 FORM SUB. [N] (24) 43			
PRIME COMP. SUPPLIER [A] (25) 44		COMPONENT MANUFACTURER [G] [1] [1] [2] (26) 45 46 47 48													

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Valve inoperability caused by Pneumatic Cylinder Piston sticking in mid-
11 position. Stuck piston and pistons of valves CV-4327A thru G lubed an
12 d tested-found sat. Valve is model LD-240-208 made by General Precision
13 Systems, Inc. CV-4327H cylinder will be re-examined during 1982 refuelin
14 g outage to determine if valves require additional preventative maint.

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

FACILITY STATUS POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)

1 5 1 3 28 0 3 7 29 NA B 31 Operator Observation

ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 5 7 33 7 34 NA NA

PERSONNEL EXPOSURES									
NUMBER		TYPE		DESCRIPTION					
1	7	0	0	0	0	37	Z	28	NA

PERSONNEL INJURIES
NUMBER DESCRIPTION (41)
1 4 0 0 0 40 NA

9		11		12		80	
TYPE		DESCRIPTION		43			
1	9	Z	42	NA			

8 9 10 80
PUBLICITY 8107140506 810701
ISSUED DESCRIPTION (45) PDR ADOCK 05000331 NRC USE ONLY
2 0 L N (44) NA S PDR

NAME OF PREPARER Arnold W. Schmich

PHONE: 319-851-5611