



Northern Indiana Public Service Company

Corporate Headquarters / 5255 Hohman Avenue / Hammond, Indiana 46320 / Tel. 853 5200 (219)

EUGENE M. SHORB
EXECUTIVE VICE PRESIDENT
AND CHIEF OPERATING OFFICER

July 7, 1981



Mr. James G. Keppler, Regional Director
U. S. Nuclear Regulatory Commission
Region III
779 Roosevelt Road
Glen Ellyn, Illinois 60137

Re: NRC IE Bulletin 81-03, dated April 10, 1981
Docket No. 50-367

Dear Mr. Keppler:

This letter is in response to IE Bulletin No. 81-03 dated April 10, 1981. Please be advised that we have determined, through a review of the results of the current field monitoring program for Bailly Generating Station Nuclear 1, that neither the Corbicula nor the Mytilus specie is present in the local environment.

Very truly yours,

EMS:cgs

cc: Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

IE 11
#10
S/0

8107140527 810707
PDR ADOCK 05000367
Q PDR

JUL 8 1981