



Northern States Power Company

414 Nicollet Mall  
Minneapolis, Minnesota 55401  
Telephone (612) 330-6071

D. E. Gilberts  
Senior Vice President  
Power Supply

June 11, 1981

Mr. James G. Keppler  
Director, Region III  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Dear Mr. Keppler:

MONTICELLO NUCLEAR GENERATING PLANT  
Docket No. 50-263 License No. DPR-22



The following is submitted as supplemental information regarding I. E.  
Bulletin No. 80-06:

In the letter to Mr. James G. Keppler, NRC, from Mr. D. E. Gilberts, NSP,  
dated June 16, 1980, it was stated that:

"With respect to Item 2, testing to verify that all equipment  
remains in its emergency mode upon removal and/or manual resetting  
of the ESF actuation signal will be completed prior to or during the  
refueling outage scheduled for April, 1981."

Testing has been completed with the exception of the Recirc Pump Discharge  
Bypass Valve, MO 2-54B, which was inoperable during ESF testing. The valve  
will be tested during the 1981 fall maintenance outage.

All equipment remained in its emergency mode except for one valve in the  
HPCI system. The HPCI Test Return Control Valve, CV 3503, opened upon  
removal of the ESF actuating signal. A redundant valve on the same line,  
MO 2071, remained in the closed position. A design change will be pursued  
that will insure that the valve remains closed. Assuming needed equipment  
is available, the modifications will be installed during the 1982 refueling  
outage.

Yours truly,

*D. E. Gilberts*  
D. E. Gilberts  
Senior Vice President  
Power Supply

8107160380 810611  
PDR ADOCK 05000263  
Q PDR

cc: Mr. C. H. Brown  
Mr. G. Charnoff  
U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Division of Reactor Operations Inspection  
Washington, D. C. 20555

*IE11*  
*510*  
JUN 15 1981

Attachment

UNITED STATES NUCLEAR REGULATORY COMMISSION

NORTHERN STATES POWER COMPANY

MONTICELLO NUCLEAR GENERATING PLANT

Docket No. 50-263

LETTER DATED JUNE 11, 1981  
RESPONDING TO NRC REQUEST  
FOR INFORMATION IN IE BULLETIN NO. 80-06

Northern States Power Company, a Minnesota corporation, by this letter dated June 11, 1981, hereby submits information in response to NRC request for information concerning IE Bulletin No. 80-06.

This request contains no restricted or other defense information.

NORTHERN STATES POWER COMPANY

By: DE Gilberts  
D. E. Gilberts  
Senior Vice President  
Power Supply

On this 11th day of June, 1981, before me a notary public in and for said County, personally appeared D. E. Gilberts, Senior Vice President Power Supply, and being first duly sworn acknowledged that he is authorized to execute this document on behalf of Northern States Power Company, that he knows the contents thereof, and that to the best of his knowledge, information and belief, the statements made in it are true and that it is not interposed for delay.

Jeanne M. Hucker

