

CONTROL BLOCK:

						1
--	--	--	--	--	--	---

 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

08 _____

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

14 | supply until the relay is repaired.

ISSUED (44) DESCRIPTION (45) N/A
PDR ADOCK 05000249
PDR
NRC USE ONLY



Commonwealth Edison

DEVIATION REPORT

DVR NO.	STA	UNIT	YEAR	NO.
D-12	-	3	-	81-36

PART 1 TITLE OF DEVIATION

3B RPS MG Set Failure to Trip on Undervoltage

OCCURRED	6/19/81	10:25
DATE		TIME

SYSTEM AFFECTED 500

PLANT CONDITIONS

Rx Protection

MODE Run

PWR (MWT) 2250

LOAD (MWE) 715

TESTING	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
---------	---	-----------------------------

DESCRIPTION OF EVENT

During RPS MG Set undervoltage relay calibration, the 3B RPS MG set failed to trip on an undervoltage signal.

DESCRIPTION OF CAUSE

Unknown at this time.

OTHER APPLICABLE INFORMATION

None

EQUIPMENT	<input checked="" type="checkbox"/> YES	DR NO.	N/A
FAILURE	<input type="checkbox"/> NO	WR NO.	14290

WR NO. 14290

Michael Wright

6/19/81

RESPONSIBLE SUPERVISOR

DATE

PART 2 OPERATING ENGINEERS COMMENTS

The 3A RPS Bus will remain on backup feed until the tripping problem is resolved.

TYPE OF DEVIATION
REPORTABLE OCCURRENCE☐ 14 DAY ☐ 10CFR21☒ 30 DAY NOTIFICATION
6.6.B.2.bEVENT OF POTENTIAL
PUBLIC INTEREST☐TECH SPEC
VIOLATION☐NON-REPORTABLE
OCCURRENCE☐ANNUAL
REPORTINGYES ☒NO ☐SAFETY-
RELATED
WR ISSUEDYES ☒NO ☐REPORTABLE OCCURRENCE
NUMBER

XXX 81-17/03L-0

ACTION ITEM NO.

PROMPT ON-SITE NOTIFICATION

R. M. Ragan

6/19/81

11:30

TITLE

DATE

TIME

TITLE

DATE

TIME

24-HOUR NRC NOTIFICATION

Courtesy

☒ TPH M. Jordan 6/19/81 1100

REGION III DATE TIME

☐ TGM REGION III & DOL DATE TIME

PROMPT OFF-SITE NOTIFICATION

F. Palmer

6/19/81

12:42

TITLE

DATE

TIME

TITLE

DATE

TIME

RESPONSIBLE COMPANY OFFICER INFORMED OF 10CFR21
CONDITIONS AND THEIR REPORT TO NRC

TITLE

DATE

TIME

REVIEW AND COMPLETED

Michael Wright

6/19/81

OPERATING ENGINEER

DATE

ACCEPTANCE BY STATION REVIEW
AS REQUIRED

DATE

RESOLUTION APPROVED AND
AUTHORIZED FOR DISTRIBUTION

J.A. Costa

7-10-81

Douglas Scott

STATION SUPERINTENDENT

7/10/81

DATE