

CONTROL BLOCK: 

--	--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

0 1 I A D A C 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 5 6 7 8 9

LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT

CON'T

7 8 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

REPORT SOURCE L 5 10 10 10 10 3 3 1 7 0 6 1 1 8 1 3 0 17 10 9 8 1 9

DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During surveillance testing RCIC Steam Line High Flow Pressure Different  
0 3 | ial Indicating switch, PDIS 2442, tripped at 100 inches of water. Techni  
0 4 | cal Specification 3.2.B requires the setpoint to be 110 plus or minus 5  
0 5 | inches. A sufficient downward drift of the low level setpoint could resu  
0 6 | It in unwarranted RCIC steam supply line isolations during system operat  
0 7 | ion. Also see RO Reports 77-52, 77-56, 77-93, and 79-30.

SYSTEM CODE C E 11		CAUSE CODE E 12		CAUSE SUBCODE E 13		COMPONENT CODE I N S I T R U 14		COMP SUBCODE S 15		VALVE SUBCODE Z 16							
EVENT YEAR 8 1		SEQUENTIAL REPORT NO. 0 2 3		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0									
ACTION TAKEN F 18		FUTURE ACTION Z 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22		ATTACHMENT SUBMITTED N 23		NPRO-4 FORM SUB. N 24		PRIME COMP. SUPPLIER N 25		COMPONENT MANUFACTURER B 0 8 0 26	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | Instrument drift. The switch was recalibrated and functionally tested \_\_\_\_\_

1 1 | PDIS 2442 is a Barton Model 288 Pressure Differential Indicating Switch. \_\_\_\_\_

1 2 | Recent surveillance tests do not indicate that further corrective action \_\_\_\_\_

1 3 | is necessary at this time. This Barton PDIS and other Barton instruments \_\_\_\_\_

1 4 | installed in the plant are the subject of a continuing design review. \_\_\_\_\_

FACILITY STATUS 1 5 F 28 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 29 30  
% POWER 0 6 5 29 NA  
OTHER STATUS 30  
METHOD OF DISCOVERY B 31 Surveillance Test  
DISCOVERY DESCRIPTION 32

ACTIVITY CONTENT  
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (35)

1 6 7 33 7 34 NA NA

PERSONNEL EXPOSURES										
NUMBER		TYPE		DESCRIPTION						
1	7	0	0	0	37	7	38	NA		

PERSONNEL INJURIES	
NUMBER	DESCRIPTION
1 1	NA

1		2		3		4		5		6		7		8		9		10		11		12	
LOSS OF OR DAMAGE TO FACILITY (43)																							
TYPE				DESCRIPTION																			
1		9		7		(42)		NA															

10  
 PUBLICITY  
 ISSUED DESCRIPTION (45)  
 2 0 N (44) NA  
 NARC USE ONLY

NRC USE ONLY