

LICENSEE EVENT REPORT

CONTROL BLOCK:

							(1)
--	--	--	--	--	--	--	-----

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	I	D	C	C	2	2	0	0	-	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5			
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT	58	

CON'T

0 1 7 8 REPORT SOURCE L 6 60 61 U 5 0 0 0 3 1 6 68 69 7 0 5 2 4 8 1 74 8 0 75 0 7 0 9 8 1 80 DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | DURING NORMAL OPERATION, AIR OPERATED CONTAINMENT ISOLATION VALVE, DCR-320,
0 3 | FOR #2 S/G BLOWDOWN FAILED WHEN IT WAS GIVEN A CLOSE SIGNAL FROM THE CONTROL
0 4 | ROOM. IT WAS VERIFIED THAT THE VALVE FAILED CLOSED AND THE UPSTREAM MANUAL
0 5 | ISOLATION VALVE WAS CLOSED IMMEDIATELY. THE FAILURE WAS SUCH THAT THIS
0 6 | CONSTITUTED AN INOPERABLE ISOLATION VALVE PER T.S. 3.6.3.1. THE ACTION
0 7 | REQUIREMENTS WERE MET. PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED.
0 8 |
7 8 9 | 80

09		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE					
[0][9]		[H][I]		[E]		[B]		[V][A][L][V][E][X]				[F]		[D]					
7 8		9 10		11 12		12 13		13 18				19 20		20 21					
(17)		EVENT YEAR				SEQUENTIAL REPORT NO.		OCCURRENCE CODE				REPORT TYPE		REVISION NO.					
LER I/O REPORT NUMBER		[8][1]		[]		[0][2][6]		[]				[L]		[0]					
21 22		23 24		25 26		27 28		29 30				31 32		33 34					
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS				ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
[A]		[Z]		[Z]		[Z]		[0][0][0][0]				[N]		[Y]		[A]		[H][0][3][5]	
33 34		35 36		37 38		39 40		41 42				43 44		45 46		47 48		49 50	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 THE VALVE ACTUATOR TO STEM COUPLING HAD APPARENTLY BEEN LOOSE, VALVE OPERATIONS

1 1 RESULTED IN FRETTING OF THE COUPLING THREADS UNTIL THE COUPLING FINALLY CAME

1 2 LOOSE FROM THE VALVE STEM. THE COUPLING, VALVE STEM AND PACKING WERE REPLACED.

1 3 THE ACTUATOR WAS ADJUSTED AND THE VALVE WAS TESTED.

1 4

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

FACILITY STATUS (28) E 5 1 % POWER (29) 0 4 8 OTHER STATUS (30) NA METHOD OF DISCOVERY (31) A DISCOVERY DESCRIPTION (32) OBSERVATION DURING VALVE LINEUP

ACTIVITY CONTENT (33) Z 1 6 RELEASED OF RELEASE (34) Z 1 AMOUNT OF ACTIVITY (35) NA LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	NA	

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	40 NA

LOSS OF OR DAMAGE TO FACILITY								
TYPE		DESCRIPTION						
1	9	Z	(42)	NA				(43)
7	8	9	10					80

PUBLICITY
 ISSUED DESCRIPTION (45) NA
 8107000212 810700
 68 69 80