

LICENSEE EVENT REPORT

UPDATE REPORT Previous Report  
Date - 01/29/81

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 I L D R S 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5  
9 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 38

CON'T  
1 REPORT SOURCE L 6 0 5 0 0 0 2 3 7 7 0 1 1 7 8 1 8 0 6 1 5 8 1 9  
80 81 DOCKET NUMBER 88 89 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

2 During local leak rate testing of containment vent line, the measured leakage was  
3 1715.55 SCFH which exceeds Tech. Spec. 4.7.A for single isolation (29.38 SCFH).  
4 Investigation showed leakage through AO-2-1601-23. No leakage was detected through  
5 any other valve. The safety significance was minimal since all leakage was con-  
6 tained in the vent line. Similar Events: 50-249/80-07. Health and safety of the  
7 public was not affected.

9 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE  
S D 11 E 12 F 13 V A L V E X 14 B 15 D 16  
9 10 11 12 13 18 19 20  
17 LER/RO REPORT NUMBER 8 1 21 22 0 0 5 24 26 0 3 28 29 X 30 1 32  
18 ACTION TAKEN 19 FUTURE ACTION 20 EFFECT ON PLANT 21 SHUTDOWN METHOD 22 HOURS 23 ATTACHMENT SUBMITTED 24 NPRO-4 FORM SUB 25 PRIME COMP. SUPPLIER 26 COMPONENT MANUFACTURER  
C 18 Z 19 Z 20 Z 21 0 0 0 0 22 N 23 Y 24 N 25 P 3 4 0 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

0 Leakage was thru the seating surface of the valve due to normal deterioration. The  
1 valve was replaced and local leak rate tested satisfactorily. No further action  
2 required.

5 FACILITY STATUS 6 H 28 7 0 0 0 10 11 12 13 OTHER STATUS 20 N/A 44 METHOD OF DISCOVERY 31 B 45 46 DISCOVERY DESCRIPTION 32 Local Leak Rate Testing 80  
6 ACTIVITY CONTENT 7 Z 33 8 Z 34 9 N/A 10 11 12 13 AMOUNT OF ACTIVITY 35 N/A 44 LOCATION OF RELEASE 36 80  
7 PERSONNEL EXPOSURES 8 0 0 0 11 12 13 TYPE 37 Z 38 DESCRIPTION 39 N/A 80  
8 PERSONNEL INJURIES 9 0 0 0 11 12 13 TYPE 40 DESCRIPTION 41 N/A 80  
9 LOSS OF OR DAMAGE TO FACILITY 10 Z 42 11 12 13 TYPE 43 DESCRIPTION 44 N/A 80  
0 PUBLICITY 1 N 44 10 11 12 13 DESCRIPTION 45 N/A 80

NRC USE ONLY

K. Zirwas

PHONE: 942-2920 Ext. 422

8107200232 810616  
PDR ADOCK 05000237  
S PDR

# SUPPLEMENT TO DVR

DVR NO.			
STA	UNIT	YEAR	NO.
D - 12	- 2	- 81	- 6

PART 1		TITLE OF EVENT		OCCURRED	
		Failure of 2-1601-23 Valve to Pass LLRT		1-17-81	1100
				DATE	TIME
REASON FOR SUPPLEMENTAL REPORT					
Update Cause Description and Corrective Actions.					
PART 2					
ACCEPTANCE BY STATION REVIEW		<u>J.A. Costa</u>		<u>John W. Siro</u>	
DATE		<u>7-5-81</u>		<u>7/8/81</u>	
SUPPLEMENTAL REPORT APPROVED AND AUTHORIZED FOR DISTRIBUTION		<u>Douglas W. Siro</u>		<u>7/9/81</u>	
		STATION SUPERINTENDENT		DATE	