

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | S | C | N | E | E | 3 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5

CONF | 01 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 2 | 8 | 7 | 7 | 1 | 1 | 2 | 3 | 8 | 0 | 8 | 0 | 2 | 1 | 9 | 8 | 1 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | On November 23, 1980 the fire detectors string B-2 went into an alarm
03 | condition. A subsequent investigation revealed no fire. The string was de-
04 | clared inoperable and a fire watch established over the affected area per
05 | Technical Specifications. The string was returned to service 1-1/2 hours
06 | later. Thus, the incident was of no significance with respect to safe
07 | operation and the health and safety of the public were not affected.

09 | SYSTEM CODE | A | B | 11 | CAUSE CODE | E | 12 | CAUSE SUBCODE | A | 13 | COMPONENT CODE | I | N | S | T | R | U | 14 | COMP. SUBCODE | E | 15 | VALVE SUBCODE | Z | 16 |

17 | LER/RO REPORT NUMBER | 8 | 0 | 22 | SEQUENTIAL REPORT NO. | 0 | 1 | 6 | 24 | OCCURRENCE CODE | 0 | 3 | 27 | REPORT TYPE | L | 30 | REVISION NO. | 1 | 32 |

ACTION TAKEN | X | 18 | FUTURE ACTION | Z | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | Z | 21 | HOURS | 0 | 0 | 0 | 0 | 37 | ATTACHMENT SUBMITTED | Y | 23 | NPRO-4 FORM 308 | Y | 25 | PRIME COMP. SUPPLIER | L | 26 | COMPONENT MANUFACTURER | X | 9 | 9 | 9 | 26 |

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | This incident was the result of dust buildup in the detector. This is a
11 | recurring problem. The detector was cleaned and verified operable before re-
12 | turning to service. There is no easy solution to this problem as long as con-
13 | struction continues at the site.

14 | FACILITY STATUS | E | 28 | % POWER | 0 | 9 | 9 | 29 | OTHER STATUS | NA | 30 | METHOD OF DISCOVERY | A | 31 | DISCOVERY DESCRIPTION | Operator Observation | 32 |

15 | ACTIVITY CONTENT RELEASED | Z | 33 | AMOUNT OF ACTIVITY | NA | 35 | LOCATION OF RELEASE | NA | 36 |

16 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | 37 | TYPE | Z | 38 | DESCRIPTION | NA | 39 |

17 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | 40 | DESCRIPTION | NA | 41 |

18 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | DESCRIPTION | NA | 43 |

19 | PUBLICITY ISSUED | N | 44 | DESCRIPTION | NA | 45 |

NRC USE ONLY

J. L. Jones

PHONE: (704) 373-8197