

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 N C M I G S 1 2 0 0 - 0 0 0 0 0 0 0 0 3 4 1 1 1 1 4 5
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CONT
01 REPORT SOURCE L 5 0 5 0 0 0 3 6 9 7 0 4 2 0 8 1 8 0 5 2 0 8 1 9
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
DOCKET NUMBER OR EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 While in Mode 3, initial fuel loading, the Channel 1 Cold Leg Injection

03 Accumulator 1D tank Level Indicator fluctuated and then failed high. The

04 accumulator was declared inoperable. This is in violation of Technical

05 Specification 3.5.1.1 and is reportable per Technical Specification

06 6.9.1.13(b). Since an independent and redundant level transmitter remained

07 operable the health and safety of the public were not affected.

08

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
S F 11 E 12 A 13 I N S I T R I U 14 T 15 Z 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

17 LER/RO REPORT NUMBER 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOUR ATTACHMENT SUBMITTED NRC-4 FORM NO. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
A 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
Z Z 0 0 0 0 Y N L B O 8 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 The level indicator failed due to a faulty transmitter. A new transmitter

11 was installed and calibrated. The system was returned to operability.

12

13

14

15 FACILITY STATUS 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
X 28 0 0 0 0 29 Mode 3 30 METHOD OF DISCOVERY 31 A 32 Operator Observation 33
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36

16 Z 32 Z 34 NA 35 NA 36

PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39
17 0 0 0 0 37 Z 38 NA 39

PERSONNEL INJURIES NUMBER DESCRIPTION 41
18 0 0 0 0 40 NA 41

LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43
19 Z 42 NA 43

PUBLICITY ISSUED DESCRIPTION 45
20 N 44 NA 45

NRC USE ONLY
68 69 70

NAME OF PREPARER R. W. Ouellette
PHONE: (704) 373-7530