

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N C M G S 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 1 1 4 5
 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
 LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT

CON'T
 0 1
 7 8
 REPORT SOURCE 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80
 DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
 0 2 While in Mode 5, initial fuel loading, the noble gas activity monitor, EMF-33,
 0 3 on the Condenser Steam Air Ejector System would not function in the "AUTO"
 0 4 mode. This is in violation of Technical Specification 3.3.3.9 and required
 0 5 implementation of an Action Statement. Since no radiation above background
 0 6 existed in this system, as confirmed by Health Physics analysis, the health
 0 7 and safety of the public were not affected.
 0 8

0 9
 7 8 9
 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE
 B B A B I N S T R U E Z
 10 11 12 13 14 15 16 17 18 19 20

17
 7 8 9
 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
 8 1 0 8 9 1 3 L 0
 21 22 23 24 25 26 27 28 29 30 31 32

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NRC-4 FORM SUB. PRIME CORP. SUPPLIER COMPONENT MANUFACTURER
 B Z Z 7 7 0 0 0 0 Y N L G 0 6 3
 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
 1 0 Since the vacuum switch had been readjusted to a more sensitive setting,
 1 1 spurious fluctuation in the system's vacuum caused the low flow alarm to
 1 2 occur. Grab samples were taken as required, the system vacuum switch was
 1 3 checked and the vacuum pump was restarted and returned to service.
 1 4

1 5
 7 8 9
 FACILITY STATUS & POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION
 X 0 0 0 0 Mode 5 A Operator Observation
 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

1 6
 7 8 9
 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE
 Z Z NA NA
 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

1 7
 7 8 9
 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION
 0 0 0 Z NA
 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

1 8
 7 8 9
 PERSONNEL INJURIES NUMBER DESCRIPTION
 0 0 0 NA
 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

1 9
 7 8 9
 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION
 Z NA
 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

2 0
 7 8 9
 PUBLICITY ISSUED DESCRIPTION
 N NA
 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

NRC USE ONLY

8107200300 NAME OF PREPARER R. W. Ouellette
PDR ADCK 810618
S 05000369
PDR

PHONE: (704) 373-7530