

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK:

[] [] [] [] []																													
[0]	[1]	N	C	M	G	S		(2)	0	0	-	0	0	0	0	0	-	0	0	(3)	4	1	1	1	1	(4)	[]	[]	:
LICENSEE CODE							LICENSE NUMBER									LICENSE TYPE								CAT					

CON'T

[0]	[1]	L	(5)	0	5	i	0	0	0	3	6	9	(7)	0	4	1	3	8	1	(8)	0	5	1	3	8	1	(9)
REPORT SOURCE		DOCKET NUMBER										EVENT DATE					REPORT DATE										

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

While in Mode 3, initial fuel loading, liquid from the Ventilation Unit
Condensation Drain Tank was released into the Condenser Discharge without prior analysis. This is in violation of Technical Specification 4.11.1.1.1 and is reportable per Technical Specification 6.9.1 13(b). An operable radiation monitor did not alarm and the analysis on the remaining contents in the tank verified that the health and safety of the public were not affected.

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COM. SUBCODE VALVE SUBCODE

[M] A (11)	[D] (12)	[Z] (13)	Z Z Z Z Z (14)	[Z] (15)	[Z] (16)				
EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.	
[8] [1] (17)	[] (18)	[0] [5] [3] (19)	[] (20)	[0] [3] (21)	[L] (22)	[] (23)	[0] (24)		
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO-4 FORM SUB PRIME COMP SUPPLIER COMPONENT MANUFACTURER	[d] [18] [H] [19]	[Z] (20)	[Z] (21)	[0] [0] [0] [0] (22)	[Y] (23)	[N] (24)	[Z] (25)	[Z] [9] [9] [9] (26)	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

This incident was caused by a deficient procedure and personnel being unaware of the proper operation of the system. The remaining contents in the tank were analyzed, a flow proportional sampler has been installed and a new procedure has been written in order to correct this situation.

FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

[X] (28)	[0] [0] [0] (29)	Mode 3 (30)	[A] (31) Personnel Observation (32)
ACTIVITY CONTENT RELEASED OR RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE			
[Z] (33)	[Z] (34) NA (35)	NA (36)	
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION PERSONNEL INJURIES NUMBER DESCRIPTION LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION PUBLICITY ISSUED DESCRIPTION			
[0] [0] [0] (37)	[Z] (38) NA (39)		
[0] [0] [0] (40)	NA (41)		
[Z] (42)	NA (43)		
[N] (44)	NA (45)		

NAME OF PREPARER R. W. Ouellette PHONE: (704) 373-7530

8107200378 810513
PDR ADCK 05000369
S PDR