

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK:										(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)																													
N   C   M   G   S   1   0   0   -   0   0   0   0   -   0   0   3   4   1   1   1   1   4   5																																							
L I C E N S E E C O D E										L I C E N S E N U M B E R										L I C E N S E T Y P E										C A T									
R E P O R T S O U R C E										D O C K E T N U M B E R										E V E N T D A T E										R E P O R T D A T E									
EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)																																							
While in Mode 3, initial fuel loading, the UHI surge tank low pressure alarm was received in the Control Room. The UHI system was determined to be inoperable. This is in violation of T.S. 3.5.1.2 and is reportable per T.S. 6.9.1.13 (b). Since there is only new fuel in the core, the health and safety of the public were not affected.																																							
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE																																							
S   F   11   E   12   B   13   V   A   L   V   E   X   14   X   15   X   16																																							
LER/RP REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.																																							
8   1   —   0   5   7   0   3   L   —   0																																							
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER																																							
E   18   B   19   Z   20   Z   21   0   0   0   0   Y   23   N   24   L   25   X   9   9   9																																							
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)																																							
Various Safety Injection Valves were found leaking. This allowed the UHI surge tank to drain down and reduce the tank pressure. The UHI surge tank has been filled as need and the leaking valves will be repaired.																																							
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION																																							
X   8   0   0   0   29   Mode 3   A   31   Operator Observation																																							
ACTIVITY CONTENT RELEASED OR RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE																																							
Z   32   Z   34   NA   NA																																							
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION																																							
0   0   0   37   Z   38   NA																																							
PERSONNEL INJURIES NUMBER DESCRIPTION																																							
0   0   0   40   NA																																							
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION																																							
Z   42   NA																																							
PUBLICITY ISSUED DESCRIPTION																																							
N   44   NA																																							
NAME OF PREPARER R. W. Ouellette																																							
NRC USE ONLY (704) 373-7530																																							

8107200385 810515  
PDR ADDCK 05000369  
S PDS