

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 N C M G S L 2 0 0 0 - 0 0 0 0 0 - 0 0 0 3 4 1 1 1 1 1 4 5
 7 8 9 14 15 25 26 30 37 CAT 38
 LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CONT
 01 REPORT SOURCE L 6 0 5 0 10 10 3 6 9 7 0 4 2 3 8 1 1 8 0 1 5 0 7 8 1 9
 7 8 9 14 15 25 26 30 37 CAT 38
 DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10
 02 Inspection/leak detection measures were assumed for postulated breaks in
 03 Loop B 10-inch Accumulator Injection line in lieu of providing structural
 04 restraints or barriers to prevent unacceptable interactions. This is in
 05 violation of the existing Licensing agreement for pipe rupture protection.
 06 Loss of functional integrity of certain Nuclear Sampling or S/G Blowdown
 07 lines could eventually result in loss of containment integrity. The
 08 health and safety of the public have not been affected.

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
 7 8 9 14 15 25 26 30 37 CAT 38
 S F 11 A 12 X 13 P 1 P E X X 14 C 15 Z 16
 17 LER/RO REPORT NUMBER 18 8 1 19 20 21 22 23 24 25 26 27 28 29 30 31 32
 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPROG FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47
 G 18 F 19 Z 20 21 22 23 24 25 26 27 28 29 30 31 32
 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27
 10 The inspection/leak detection program was considered applicable to
 11 Loop B 10-inch Accumulator Injection Line contrary to the existing
 12 Licensing agreement. The program applicable to the other 10-inch
 13 Accumulator Injection lines will be implemented. The affected design
 14 document will be revised. An affected electrical cable will be rerouted.

15 FACILITY STATUS 16 % POWER 17 OTHER STATUS 18 METHOD OF DISCOVERY 19 DISCOVERY DESCRIPTION 20
 7 8 9 14 15 25 26 30 37 CAT 38
 X 28 0 0 0 29 initial fuel C 31 Personnel Observation 32
 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47
 ACTIVITY CONTENT RELEASED OR RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE
 1 6 Z 33 Z 34 NA 35 NA 36
 7 8 9 14 15 25 26 30 37 CAT 38
 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39 NA
 1 7 0 0 0 17 Z 38 39
 7 8 9 14 15 25 26 30 37 CAT 38
 PERSONNEL INJURIES NUMBER DESCRIPTION 41 NA
 1 8 0 0 0 40 41
 7 8 9 14 15 25 26 30 37 CAT 38
 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43 NA
 1 9 Z 42 43
 7 8 9 14 15 25 26 30 37 CAT 38
 PUBLICITY ISSUED DESCRIPTION 45 NA
 2 0 N 44 45
 7 8 9 14 15 25 26 30 37 CAT 38
 NAME OF PREPARER R.W. Ouellette
 PHONE: (704) 373-7530