

## LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | S | C | N | E | E | 2 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

CONT  
01 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 2 | 7 | 0 | 7 | 0 | 5 | 0 | 8 | 8 | 1 | 8 | 0 | 6 | 0 | 8 | 8 | 1 | 9

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | On May 8, 1981 the "Auto/Manual Select" solenoid valve for 2FDW-316 was dis-

03 | covered stuck in the manual position, thus disabling automatic level control

04 | of the B "OTSG" from the (EFW) System. Only one steam generator is required for

05 | a safe cool down of the RC System. This requirement was met by the operability

06 | of 2FDW-315 to "OTSG A". Additionally, manual operation of 2FDW-316 was not

07 | affected and operator control of EFW to Steam Generator was available. Thus,

08 | this incident was of no significance with respect to safe operation, and the

09 | health and safety of the public were not affected.

09 | SYSTEM CODE | H | H | 11 | CAUSE CODE | F | 12 | CAUSE SUBCODE | B | 13 | COMPONENT CODE | V | A | L | V | E | X | 14 | COMP. SUBCODE | X | 15 | VALVE SUBCODE | E | 16

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

17 | LER/RO REPORT NUMBER | 8 | 1 | 1 | EVENT YEAR | 8 | 1 | 1 | SEQUENTIAL REPORT NO. | 0 | 0 | 8 | OCCURRENCE CODE | 0 | 3 | REPORT TYPE | L | REVISION NO. | 0

18 | ACTION TAKEN | B | 18 | FUTURE ACTION | Z | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | Z | 21 | HOURS | 0 | 0 | 0 | 0 | ATTACHMENT SUBMITTED | Y | 22 | NPRO-4 FORM SUB. | Y | 24 | PRIME COMP. SUPPLIER | L | 25 | COMPONENT MANUFACTURER | V | 0 | 3 | 0 | 28

13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The cause of this incident was the stuck Valcor solenoid valve. The solenoid

11 | valve was replaced per procedure. All functions were normal.

12 |

13 |

14 |

15 | FACILITY STATUS | E | 28 | % POWER | 1 | 0 | 0 | 29 | OTHER STATUS | NA | 30 | METHOD OF DISCOVERY | B | 31 | DISCOVERY DESCRIPTION | Performance of on-line functional test. | 32

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

16 | ACTIVITY CONTENT RELEASED OR RELEASE | Z | 33 | AMOUNT OF ACTIVITY | NA | 35 | LOCATION OF RELEASE | NA | 36

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

17 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | 37 | TYPE | 38 | DESCRIPTION | NA | 39

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

18 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | 40 | DESCRIPTION | NA | 41

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

19 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | DESCRIPTION | NA | 43

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

20 | PUBLICITY ISSUED DESCRIPTION | N | 44 | NA | 45

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

21 | NRC USE ONLY

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32