NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | N C M G S 1 | 0 0 - 0 0 0 0 0 - 0 0 | 4 1 1 1 1 | LICENSEE CODE | LICENSE NUMBER | LICENSE TYPE | CAT 58

CON'T 01 | REPORT SOURCE L | 0 5 0 0 0 3 6 9 | 0 4 1 0 8 1 | 0 5 1 0 8 1 | DOCKET NUMBER | EVENT DATE | REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While in Mode 3, initial fuel loading, the Waste Processing Panel lost AC
03 power. The Containment Floor and Equipment Sump Level indicators in the
04 Control Room failed. This is in violation of T.S. 3.4.7.1 and is
05 reportable per T. S. 6.9.1.13 (b). Since there was no excessive leakage
06 at this time the health and safety of the public were not affected.
07
08

09 | SYSTEM CODE I F (11) | CAUSE CODE A (12) | CAUSE SUBCODE C (13) | COMPONENT CODE I N S T R U (14) | COMP. SUBCODE I (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER | EVENT YEAR 8 1 | SEQUENTIAL REPORT NO. 0 4 9 | OCCURRENCE CODE 0 3 | REPORT TYPE L | REVISION NO. 0

ACTION TAKEN B (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0 0 0 0 (22) | ATTACHMENT SUBMITTED Y (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER Z (25) | COMPONENT MANUFACTURER Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 AC power was lost to the Waste Processing panel due to a power supply
11 cable not being properly terminated. The cable armor was stripped
12 and the wire was taped and properly terminated. The system was returned
13 to operability.
14

15 | FACILITY STATUS X (28) | % POWER 0 0 0 (29) | OTHER STATUS (30) Mode 3 | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operator observation

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 | PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 | PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION NA (43)

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

NAME OF PREPARER R.W. Ouellette PHONE: (704) 373-7530

8107200431 810507
PDR ADOCK 05000369
S PDR