

ENCLOSURE
SEQUOYAH NUCLEAR PLANT UNIT 1
PROPOSED TECHNICAL SPECIFICATION

PLANT SYSTEMS

3/4.7.5 ULTIMATE HEAT SINK

LIMITING CONDITION FOR OPERATION

3.7.5 The ultimate heat sink shall be OPERABLE with the average temperature of water at the ERCW system suction of less than or equal to 83°F.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With the average temperature of the water at the ERCW system suction greater than 83°F be in at least HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIRMENTS

4.7.5 The ultimate heat sink shall be determined OPERABLE at least once per 24 hours by verifying the average temperature to be within its limits.

8107200433 810714
PDR ADOCK 05000327
PDR