

## LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | N | C | M | G | S | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5

LICENSEE CODE      LICENSE NUMBER      LICENSE TYPE      CAT

CONT.

0 1 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 6 | 9 | 7 | 0 | 4 | 1 | 7 | 8 | 1 | 8 | 0 | 5 | 1 | 7 | 8 | 1 | 9

DOCKET NUMBER      EVENT DATE      REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While in Mode 3, initial fuel loading, the inner door of the lower  
03 personnel air lock would not close completely and was therefore declared  
04 operable. This is in violation of T.S. 3.6.1.3 and is reportable per  
05 T.S. 6.9.1.13(b). The outer door remained operable, therefore, the  
06 health and safety of the public were not affected.  
07  
08

SYSTEM CODE S 9		CAUSE CODE E 11		CAUSE SUBCODE B 12		COMPONENT CODE P E N E T R 14		COMP SUBCODE A 15		VALVE SUBCODE Z 16	
LER/RO REPORT NUMBER 17		EVENT YEAR 8 1		SEQUENTIAL REPORT NO. 0 5 6		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0	
ACTION TAKEN X 18		FUTURE ACTION Z 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 22		ATTACHMENT SUBMITTED 1 23	
NPRO-4 FORM SUB. N 24		PRIME COMP SUPPLIER L 25		COMPONENT MANUFACTURER W 3 0 1 2							

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The apparent cause of the failure could not be readily determined. The

1 1 door was cycled several times and was found to be functioning properly.

1 2

1 3

1 4

FACILITY STATUS										% POWER										OTHER STATUS										METHOD OF DISCOVERY										DISCOVERY DESCRIPTION									
1 5 X 28										0 0 0 29 Mode 3										A 31										Personnel Observation 32																			
ACTIVITY CONTENT										RELEASED OF RELEASE										AMOUNT OF ACTIVITY										LOCATION OF RELEASE																			
1 6 Z 32 Z 34 NA										NA 35										NA 36																													
PERSONNEL EXPOSURES										PERSONNEL INJURIES										PERSONNEL EXPOSURES										PERSONNEL INJURIES																			
NUMBER TYPE DESCRIPTION										NUMBER TYPE DESCRIPTION										NUMBER TYPE DESCRIPTION										NUMBER TYPE DESCRIPTION																			
1 7 0 0 0 37 Z 38 NA										0 0 0 40 NA										0 0 0 42 NA										0 0 0 44 NA																			
LOSS OF OR DAMAGE TO FACILITY										LOSS OF OR DAMAGE TO FACILITY										LOSS OF OR DAMAGE TO FACILITY										LOSS OF OR DAMAGE TO FACILITY																			
TYPE DESCRIPTION										TYPE DESCRIPTION										TYPE DESCRIPTION										TYPE DESCRIPTION																			
1 9 Z 42 NA										NA 43										NA 44										NA 45																			
PUBLICITY										PUBLICITY										PUBLICITY										PUBLICITY																			
ISSUED DESCRIPTION										ISSUED DESCRIPTION										ISSUED DESCRIPTION										ISSUED DESCRIPTION																			
2 0 N 44 NA										NA 45										NA 46										NA 47																			

NRC USE ONLY

8107200434 810515  
PDR ADOCK 05000369  
S PDR

NAME OF PREPARER

R. W. Ouellette

PHONE: (704) 373-7530