

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	M	G	S	1	2	0	0	-	0	0	0	0	0	0	3	4	1	1	1	1	4	5										
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32										
LICENSEE CODE												LICENSE NUMBER												LICENSE TYPE										CAT	

0	1	R	E	P	O	R	T	S	O	U	R	C	E	0	5	0	0	0	3	6	9	7	0	4	1	1	8	1	8	0	5	1	1	8	1	9									
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42										
REPORT SOURCE												DOCKET NUMBER												EVENT DATE												REPORT DATE									

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 While in Mode 3; initial fuel loading, containment pressure exceeded
0 3 the limits specified by T.S. 3.6.1.4 by .005 psig. This is reportable
0 4 per T.S. 6.9.1.13 (b). This event occurred just prior to a scheduled
0 5 gaseous release through the Containment Air Addition & Release System.
0 6 The health and safety of the public were not affected.
0 7
0 8

0	9	Z	Z	11	A	12	A	13	Z	Z	Z	Z	Z	14	Z	15	Z	16	17	8	1	0	5	0	0	3	L	0	21	0	18	Z	19	Z	20	Z	21	0	0	0	0	Y	22	N	24	Z	25	Z	26	9	9
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50								
SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE										COMP. SUBCODE		VALVE SUBCODE		LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIA REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.		ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPROW FORM SUB.		PROMP. SUPPLIER		COMPONENT MANUFACTURER			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 There was an insufficient amount of lead time given to perform
1 1 the necessary sampling, analysis and reporting to the appropriate
1 2 individuals. A controlled release was initiated and the containment
1 3 pressure was reduced to within Technical Specification limits.
1 4

1	5	X	28	0	0	0	29	Mode 3	30	A	31	Operator Observation	32	1	6	Z	33	Z	34	NA	35	NA	36	1	7	0	0	0	37	Z	38	NA	39	1	8	0	0	0	40	NA	41	1	9	Z	42	NA	43	2	0	N	44	NA	45	50
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50											
FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION		ACTIVITY CONTENT		AMOUNT OF ACTIVITY		LOCATION OF RELEASE		PERSONNEL EXPOSURES NUMBER		TYPE		DESCRIPTION		PERSONNEL INJURIES NUMBER		DESCRIPTION		LOSS OF OR DAMAGE TO FACILITY TYPE		DESCRIPTION		PUBICITY ISSUED		DESCRIPTION		NRC USE ONLY																				

NAME OF PREPARER R.W. Ouellette

PHONE: (704) 373-7530