

SPECIAL
LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 MIDCC1200-00000-0034111145

7 8 9 14 15 25 26 30 57 CAT 58

CON'T
01 REPORT SOURCE L605000315707018180710819

60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 DURING THE PERFORMANCE OF SURVEILLANCE TESTING, A PINHOLE NON-ESSENTIAL
03 SERVICE WATER LEAK WAS DISCOVERED IN THE INTEGRAL RETURN HEADER OF THE
04 COPPER COOLING COIL OF 1-HV-CIR-2, INSTRUMENT ROOM VENTILATION UNIT.
05 THIS REPORT IS BEING MADE IN ACCORDANCE WITH THE REQUIREMENTS OF
06 IE BULLETIN #80-24.
07
08

80

09 SYSTEM CODE AA11 CAUSE CODE B12 CAUSE SUBCODE B13 COMPONENT CODE HTEXCH14 COMP. SUBCODE C15 VALVE SUBCODE Z16

9 10 11 12 13 18 19 20

17 LER/RO REPORT NUMBER 81 21 22 23 24 25 26 27 28 29 30 31 32

21 22 23 24 25 26 27 28 29 30 31 32

ACTION TAKEN D18 FUTURE ACTION Z19 EFFECT ON PLANT Z20 SHUTDOWN METHOD Z21 HOURS 0000 ATTACHMENT SUBMITTED N23 NPD-4 FORM SUB. N24 PRIME COMP. SUPPLIER A25 COMPONENT MANUFACTURER A22026

33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 THE PROBABLE CAUSE OF THE FAILURE IN THE TUBING WAS A MINOR IMPERFECTION
11 THAT OCCURRED DURING THE MANUFACTURING PROCESS. THE AFFECTED AREA WAS
12 REPAIRED BY SILVER BRAZING. CHARACTERISTICS OF THE DEFECT DID NOT
13 INDICATE A GENERIC PROBLEM AND THERE HAVE BEEN NO PREVIOUS OCCURRENCES.
14 NO FURTHER ACTION IS PLANNED.

80

15 FACILITY STATUS H28 % POWER 00029 OTHER STATUS NA 30 METHOD OF DISCOVERY B31 DISCOVERY DESCRIPTION PERFORMANCE ENGINEER OBSERVATION 32

7 8 9 10 11 12 13 44 45 46 80

16 ACTIVITY CONTENT RELEASED OF RELEASE Z33 Z34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

7 8 9 10 11 44 45 80

17 PERSONNEL EXPOSURES NUMBER 00037 TYPE Z38 DESCRIPTION NA 39

7 8 9 11 12 13 80

18 PERSONNEL INJURIES NUMBER 00040 DESCRIPTION NA 41

7 8 9 11 12 80

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z42 DESCRIPTION NA 43

7 8 9 10 80

20 PUBLICATION ISSUED DESCRIPTION NA 45

7 8 9 10 80

8107210247 810713
PDR ADDOCK 05000315
S PDR

NRC USE ONLY

NAME OF PREPARER ROBERT H. PIEHL

PHONE: 616-465-5901, EXT. 1036