

## (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

NAME OF PREPARED: Ben Schroeder  
PHONE: 815-942-2920 Ext. 548



Commonwealth Edison

## DEVIATION REPORT

DVR NO. STA UNIT YEAR NO.  
D-12-3-81-35

## PART 1 TITLE OF DEVIATION

Unit 3 Reactor Vessel Low Level Half Scram and Low-Low Isolation

OCCURRED  
6-18-81 1400  
DATE TIME

SYSTEM AFFECTED 500

PLANT CONDITIONS

Rx Protection

MODE Run PWR(MWT) 2487

LOAD(MWE) 804 TESTING ☒ YES ☐ NO

## DESCRIPTION OF EVENT

While conducting routine surveillance DIS #500-2 on LIS 3-263-57A, it was found that the low level scram was set greater than 66.8" W.C. and the low-low water level was set greater than 114.5" W.C.

## DESCRIPTION OF CAUSE

Test equipment checks out OK; cause unknown.

## OTHER APPLICABLE INFORMATION

Reset low water level half scram from 69.5" W.C. to 63" W.C. and a repeated test showed the low-low isolation to return to 112.7" W.C.

EQUIPMENT ☐ YES  
FAILURE ☒ NO

DR NO.  
N/A

WR NO.  
N/A

Donald C. Riersen  
RESPONSIBLE SUPERVISOR

6/18/81  
DATE

## PART 2 OPERATING ENGINEERS COMMENTS

The level switches were immediately recalibrated and repeatability was verified.

TYPE OF DEVIATION  
REPORTABLE OCCURRENCE

☐ 14 DAY ☐ 10CFR21

☒ 30 DAY NOTIFICATION  
6.6.B.2.a

EVENT OF POTENTIAL  
PUBLIC INTERESTTECH SPEC  
VIOLATIONNON-REPORTABLE  
OCCURRENCEANNUAL  
REPORTINGYES ☒NO ☐SAFETY-  
RELATED  
WR ISSUEDYES ☐NO ☒REPORTABLE OCCURRENCE  
NUMBER

XXX 81-16/03L-0

## ACTION ITEM NO.

## PROMPT ON-SITE NOTIFICATION

R. M. Ragan

6/19/81

11:30

TITLE

DATE


TIME

TITLE

DATE

TIME


## 24-HOUR NRC NOTIFICATION



REGION III

DATE

TIME



REGION III &amp; DOL

DATE

TIME

## PROMPT OFF-SITE NOTIFICATION

F. A. Palmer

6/19/81

12:40

TITLE

DATE

TIME

TITLE

DATE

TIME

RESPONSIBLE COMPANY OFFICER INFORMED OF 10CFR21  
CONDITIONS AND THEIR REPORT TO NRC

TITLE

DATE

TIME

## REVIEW AND COMPLETED

Michael Wright  
OPERATING ENGINEER

6/19/81

DATE

ACCEPTANCE BY STATION REVIEW  
AS REQUIRED

DATE

RESOLUTION APPROVED AND  
AUTHORIZED FOR DISTRIBUTION

SA Custer  
7-9-81  
Douglas Scott  
7-10-81  
STATION SUPERINTENDENT

7/10/81  
DATE