

LICENSEE EVENT REPORT

CONTROL BLOCK: 

--	--	--	--	--	--

 (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	T N S N P 1												2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5								
7	8	LICENSEE CODE												14	LICENSE NUMBER												25	LICENSE TYPE												30	CAT		56

CON'T

REPORT SOURCE: 0 1 2 8

DOCKET NUMBER: L 6 0 5 0 0 0 3 2 7 7 0 6 1 9 8 1 8 0 7 1 5 8 1 9

EVENT DATE: 60 61 68 69 74 75

REPORT DATE: 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | At 2200 CDT on 6-19-81 with Unit 1 at 100%, the liquid radwaste effluent monitor was

0 3 | declared inoperable during a pre-release source check when it would not source check.

0 4 | Unit 1 entered action statement 30 of LCO 3.3.3.9. There was no effect on public heal

05 | or safety. Refer to SQRO-50-327/81057 for report of last occurrence.

06

0	7	
---	---	--

08 \_\_\_\_\_

7 8

SYSTEM CODE

9 10

CAUSE CODE

11 12

CAUSE SUBCODE

13 14

COMPONENT CODE

15 16

COMP SUBCODE

17 18

VALVE SUBCODE

19 20

17 LER/RO REPORT NUMBER [ 8 | 1 ] 21 22 [ — ] 23  
 SEQUENTIAL REPORT NO. [ 0 | 6 | 8 ] 24 25 26 [ / ] 27  
 OCCURRENCE CODE [ 0 | 3 ] 28 29  
 REPORT TYPE [ L ] 30 [ — ] 31  
 REVISION NO. [ 0 ] 32

ACTION TAKE# FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPND-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURE

C 18 F 19 Z 20 Z 21 0 0 0 0 N 23 N 24 L 25 G 0 6

33 34 35 36 37 40 41 42 43 44

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The monitor sample chamber was contaminated due to background buildup. The chamber

1 1 requires frequent flushing and replacement of the sample chamber. On this occasion, t

1 2 sample chamber was replaced and the monitor was returned to service at 1000 CDT on

1 3 6/23/81. Design modifications to facilitate flushing (DCR-908) and to provide a

1 4 | redundant monitor (DCR-1109) are being processed.

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION				
1	5	E	28	1	0	0	29	NA	B	31	Source Check	32

ACTIVITY CONTENT  
RELEASED OF RELEASE

1 6 2 33 2 34 NA

AMOUNT OF ACTIVITY (35)

NA

LOCATION OF RELEASE (36)

PERSONNEL EXPOSURES									
NUMBER			TYPE		DESCRIPTION				
1	7	0	0	0	17	Z	38	NA	

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	NA

LOSS OF OR DAMAGE TO FACILITY		(43)
TYPE	DESCRIPTION	
19	2	NA

8107210362 810715

PURCHASER'S NAME  
ISSUED DESCRIPTION NA PDR ADLOCK 05000327 S PDR NRC USE ONLY

Name of Preparer: M. R. Harding/A. M. Wilkey

Phone: (615) 842-8317