



Consumers
Power
Company

James W Cook
Vice President - Projects, Engineering
and Construction

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0453

June 30, 1981

Mr J G Keppler
US Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137



MIDLAND PROJECT
DOCKET NO 50-329 AND DOCKET NO 50-330
IE BULLETIN 81-03
FILE: 0505.12 UFI: 99*02*05*10 SERIAL: 12806

IE Bulletin 81-03, "Flow Blockage of Cooling Water to Safety System Components by Corbicula Sp. (Asiatic Clam) and Mytilus Sp. (Mussel)," requires Consumers Power Company to determine whether these species are present in the vicinity of the Midland Plant in either the source water or receiving water and to take appropriate action accordingly.

Consumers Power Company contracted Ecological Analysts, Inc to survey the Midland Plant environment for the presence of Corbicula. Mytilus is a salt water species and therefore not included in this assessment. No Corbicula was observed at the Midland Plant site. A report pertaining to the survey conducted at the Midland Plant is included as Attachment A.

Based on the discussion and results of attachment, we consider the action required by this bulletin to be complete.

JW Cook for JWC
JWC/WJH/db

CC: RJCook, Midland Resident Inspector, w/a
DSHood, NRC, w/a
DBMiller, Midland, w/a (3)
NCMoseley, NRC, w/a

Attachment

IE11
5
1/1

8107210364 810630
PDR ADOCK 05000329
Q PDR

JUL 6 1981