

CONTROL BLOCK: 1


(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

OFFICIAL COPY

0 1 A L J M F 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 58REPORT SOURCE L 5 0 5 0 0 0 3 6 4 7 0 6 1 1 8 1 3 0 7 1 3 8 1 9
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

At 0750 on 6/11/81, it was discovered that FNP-2-STP-23.8 (Component Cooling Water Valve Inservice Test) had not been performed, in its entirety, within the time interval specified by Tech. Spec. Surveillance requirement 4.0.5 (quarterly). Health/safety of the public was not affected by this event.



SYSTEM CODE Z Z 11 CAUSE CODE A 12 CAUSE SUBCODE A 13 COMPONENT CODE Z Z Z Z Z Z 7 14 COMP SUBCODE Z 15 VALVE SUBCODE Z 16
EVENT YEAR 8 1 SEQUENTIAL REPORT NO. 0 2 4 OCCURRENCE CODE 0 3 REPORT TYPE L REVISION NO. 0
LER-RO REPORT NUMBER 17
ACTION TAKEN X 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPRO-4 FORM SUB. N 24 PRIME COMP. SUPPLIER Z 25 COMPONENT MANUFACTURER Z 9 9 9 9 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

FNP-2-STP-23.8 was performed, in part, on 3/9/81 following maintenance of the makeup valves to the Surge Tank. However, the test schedule did not indicate that it had only been partially performed. FNP-2-STP-23.8 was successfully performed on 6/12/81. This event will be discussed with individuals involved.

FACILITY STATUS G 29 % POWER 0 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Surveillance Schedule Review 32
ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 NA AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39
PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41
LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43
PUBLICITY ISSUED N 44 DESCRIPTION NA 45
8107210366 810713
PDR ADOCK 05000344
S PDR
NRC USE ONLY
NAME OF PREPARER W. G. Hairston, III PHONE: (205)899-5156