



Docket No. 50-346  
License No. NPF-3  
Serial No. 731  
July 10, 1981

RICHARD P. CROUSE  
Vice President  
Nuclear  
(419) 258-5221



Director of Nuclear Reactor Regulation  
Attention: Mr. John F. Stolz  
Operating Reactor Branch No. 4  
Division of Operating Reactors  
United States Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Mr. Stolz:

Under separate cover, we are transmitting three (3) original and forty (40) conformed copies of an application for Amendment to Facility Operating License No. NPF-3 for the Davis-Besse Nuclear Power Station Unit No. 1.

This application requests that the Davis-Besse Nuclear Power Station Unit 1 Technical Specifications, Appendix A, be revised to reflect the changes attached. The proposed changes include:

1. Changes in Section 4.7.1.2.d;
2. Changes in Sections 3.4.2, 3.4.3, 4.4.3 and Bases;
3. Changes in Sections 4.8.1.1.2.C.2 and 4.8.1.2;
4. Changes in Sections 3.1.3.6, 3.2.1, 3.2.5, and Figures 3.1-3a;
5. Changes in Section 6.5.2.2, Figures 6.2-1 and 6.2-2;
6. Changes in Section 3.7.10.

The six attachments identify the proposed changes and their safety evaluations. Item 1 concerns the Surveillance Requirements on the Auxiliary Feedwater Pump Turbine Speed Switches. Item 2 concerns the setpoint index for pressurizer electromatic relief and code safety valves. Item 3 concerns Surveillance Requirements for the Emergency Diesel Generator as requested in Inspection Report 50-346/ 80-29 and load rejection capabilities. Item 4 concerns administrative errors in Technical Specifications and a revised safety evaluation for Toledo Edison's amendment request submitted February 11, 1980 (Serial No. 590).

*Acc'l  
s  
1/1  
with check:*

*12000.00*


Docket No. 50-346  
License No. NPF-3  
Serial No. 731  
July 10, 1981

-2-

Item 5 concerns a revision to the amendment request dated December 26, 1980 (Serial 669) which reflected the reorganization of Toledo Edison. Item 6, which concerns the Fire Barrier Penetration is in response to Mr. R. W. Reid's letter dated September 23, 1980 (Log No. 609) and additional information requested to complete our submittal dated December 26, 1980 (Log 669).

This amendment requests three changes of Class III type and three changes requiring no fees. Items 4, 5, and 6 consist of technical errors and required additional information or revisions to previous submittals. It is therefore determined to be a Class III amendment. Enclosed is a check for \$12,000 as requested by 10CFR170.22.

Very truly yours,



RPC:GAB

Attachment

pp b/2-3

cc:  
DB-1 NRC Resident Inspector