

John D. O'Toole
Vice President

Consolidated Edison Company of New York, Inc.
4 Irving Place, New York, NY 10003
Telephone (212) 480-2533

July 10, 1981

Re: Indian Point Unit No. 2
Docket No. 50-247

Mr. Boyce H. Grier, Director
Office of Inspection and Enforcement
Region I
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pa. 19406



Dear Mr. Grier:


By letter dated March 26, 1981 we provided our response to IE Bulletin No. 80-06. Enclosure 1 to that letter (item no. 6) identified valves FCV-1111 and FCV-1112 as reverting to the non-safeguards mode upon resetting of the ESF actuation signal. Plans for modifying the actuation circuitry to preclude these valves from reverting upon resetting of the ESF signal were provided in Enclosure 2 to that letter.

During the recently completed refueling outage, previously planned modifications were implemented, changing the actuation of these valves from automatic to manual. Since these modifications rendered these valves independent of the ESF actuation signal and ESF reset, the planned revert changes to the FCV-1111 and FCV-1112 actuation circuits were no longer required and were not performed.

IEH
s
1/0

This information is provided pursuant to 10CFR50.54(f) as was our previous response. Should you or your staff any additional questions, please contact us.

Very truly yours,



John D. O'Toole
Vice President

Subscribed and sworn to
before me this 10 day
of July, 1981.



Notary Public
MARGARET A. HLINKA
Notary Public, State of N. Y.
No. 24-4622606
Qualified in Kings County
Commission Expires March 30, 1983

cc: Office of Inspection and Enforcement
Division of Reactor Operations Inspection
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. T. Rebelowski, Resident Inspector
U. S. Nuclear Regulatory Commission
P. O. Box 38
Buchanan, N. Y. 10511

Director of Nuclear Reactor Regulation
Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555