



CHARLES CENTER • P. O. BOX 1475 • BALTIMORE, MARYLAND 21203

July 14, 1981

ARTHUR E. LUNDVALL, JR.  
VICE PRESIDENT  
SUPPLY

Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Attn: Mr. D. G. Eisenhut, Director  
Division of Licensing

Subject: Calvert Cliffs Nuclear Power Plant  
Units Nos. 1 & 2, Dockets Nos. 50-317 & 50-318  
Response to NUREG-0737 Item II.K.3.2

Reference: (a) Letter from A. E. Lundvall, Jr. to  
D. G. Eisenhut dated February 20, 1981.



Gentlemen:

Reference (a) forwarded CEN-145, PORV Failure Reduction  
Methods. This report requires correction.

On page 8, the total number of MSSV demands is incorrectly  
reported to be 5650. The actual number is 4650 demands (the sum of  
2070 MSSV test demands and 2580 operational demands). This also changes  
the failure rate from  $1.24 \times 10^{-3}$  to  $1.5 \times 10^{-3}$  per demand.

The conclusion of the report, that the failure rate is lower  
than the value of  $2 \times 10^{-2}$  per demand estimated in NUREG-0560, remains  
valid.

Very truly yours,

A. E. Lundvall, Jr.  
Vice President-Supply

cc: J. A. Biddison, Esquire  
G. F. Trowbridge, Esquire  
Messrs. E. L. Conner, Jr. - NRC  
R. E. Architzel - NRC Resident Inspector

A046  
s  
1/0