

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--

1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	I	D	C	C	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT 58	

CON'T

0	1	REPORT SOURCE										DOCKET NUMBER										EVENT DATE										REPORT DATE									
7	8	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80																			

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | DURING PERFORMANCE OF INACCESSIBLE HYDRAULIC SNUBBER SURVEILLANCE, FEEDWATER

0 3 | SNUBBER 1-FWS-1 WAS FOUND TO HAVE ROTATED TO A POSITION ALLOWING AIR TO ENTER

0 4 | THE FLUID INLET PORTS. DURING FUNCTIONAL BENCH TEST, THE SNUBBER FAILED TO

0 5 | LOCKUP IN EITHER COMPRESSION OR TENSION AND WAS DECLARED AN INSPECTION FAILURE

0 6 | PER T.S. 4.7.8.1.1. HEALTH AND SAFETY OF THE PUBLIC WAS NOT AFFECTED. A SIMILAR

0 7 | OCCURRENCE WAS REPORTED AS RO 78/086/03L-0 FOR DOCKET 050-0316.

08 _____ 80

SYSTEM CODE [0] [9]		CAUSE CODE [Z] [Z]		CAUSE SUBCODE [A]		COMPONENT CODE [S] [U] [P] [O] [R] [T]				COMP SUBCODE [D]		VALVE SUBCODE [Z]	
7	8	9	10	11	12	13	14	15	16	17	18	19	20
LER/RO REPORT NUMBER [17]		EVENT YEAR [8] [1]		SEQUENTIAL REPORT NO. [0] [2] [2]		OCCURRENCE CODE [/]		REPORT TYPE [0] [3]		REVISION NO. [0]			
21	22	23	24	25	26	27	28	29	30	31	32		
ACTION TAKEN [E]		FUTURE ACTION [H]		EFFECT ON PLANT [Z]		SHUTDOWN METHOD [Z]		HOURS [0] [0] [0] [0]		ATTACHMENT SUBMITTED [N]		NPRD-4 FORM SUB. [N]	
33	34	35	36	37	38	39	40	41	42	43	44	45	46
PRIME COMP. SUPP. IER [A]		COMPONENT MANUFACTURER [I] [2] [0] [7]											
47	48	49	50	51	52	53	54	55	56	57	58	59	60

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | WORK WAS IN PROGRESS IN THE AREA AND SNUBBER MAY HAVE BEEN BUMPED OR STEPPED ON,
1 1 | CAUSING THE EXTENSION ARM LOCKNUT TO LOOSEN. THE SNUBBER WAS REFILLED, BLED,
1 2 | TESTED AND REINSTALLED WITH NUTS TIGHTENED AND STAKED. LETTER SENT TO DEPART-
1 3 | MENT HEADS REQUESTING PERSONNEL BE CAUTIONED TO USE CARE NEAR HYDRAULIC SNUBBER
1 4 | INSTALLATIONS. INSPECTION FREQUENCY CHANGED PER T.S. TABLE 4.7-9.

7	8	9											80			
FACILITY STATUS			% POWER			OTHER STATUS			METHOD OF DISCOVERY			DISCOVERY DESCRIPTION			32	
1	5	H	28	0	0	0	29	NA			B	31	MAINTENANCE PERSONNEL OBSERVATION			80

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 Z 33 Z 34 NA

AMOUNT OF ACTIVITY (35)

LOCATION OF RELEASE (36)

PERSONNEL EXPOSURES										
NUMBER		TYPE		DESCRIPTION						
1	7	0	0	0	37	Z	38	NA		

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	NA

1 9		Z		42		43	
TYPE		DESCRIPTION					
				NA			

7 8 9 10 PUBLICITY PDR ADOCK 05000315 8107240153 810717 NA S PDR NRC USE ONLY

NAME OF PREPARER R. H. PIEHL

PHONE: 616-465-5901, EXT. 1036