



Commonwealth Edison

DEVIATION REPORT

DVR NO.	STA	UNIT	YEAR	NO.
D-12	-	3	-	81-37

PART 1 TITLE OF DEVIATION Unit 3 Rx Lo-Lo Water Level ECCS Initiate Level Switch 3-263-72B Out of Calibration		OCCURRED 6/19/81 1415 DATE TIME	
SYSTEM AFFECTED Rx Protection	PLANT CONDITIONS MODE Run PWR(MWT) 2373 LOAD(MWE) 767	TESTING <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	

DESCRIPTION OF EVENT
 LIS 3-263-72B found to trip at 115.5" W.C. increasing. Tech. Spec. Limit is 84 (+4/-0) inches
 above actual fuel (114.5" W.C. max.)

DESCRIPTION OF CAUSE
 Mechanical drift possible due to warm Rx. building temp.

OTHER APPLICABLE INFORMATION
 Completed DIP 010-9 and reset switches to trip at 111.6" W.C. increasing and verified repeatability

EQUIPMENT FAILURE	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	DR NO. N/A	WR NO. N/A	Alan R. Zapatocky RESPONSIBLE SUPERVISOR	6/19/81 DATE
-------------------	--	---------------	---------------	---	-----------------

PART 2 OPERATING ENGINEERS COMMENTS
 The level switch was immediately reset & repeatability verified.

TYPE OF DEVIATION REPORTABLE OCCURRENCE <input type="checkbox"/> 14 DAY <input type="checkbox"/> 10CFR21 <input checked="" type="checkbox"/> 30 DAY NOTIFICATION 6.6.B.2.a	EVENT OF POTENTIAL PUBLIC INTEREST <input type="checkbox"/>	TECH SPEC VIOLATION <input type="checkbox"/>	NON-REPORTABLE OCCURRENCE <input type="checkbox"/>	ANNUAL REPORTING YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	SAFETY- RELATED WR ISSUED YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
REPORTABLE OCCURRENCE NUMBER 81-18/03L-0	ACTION ITEM NO.	PROMPT ON-SITE NOTIFICATION R. M. Ragan 6/22/81 0900 TITLE DATE TIME TITLE DATE TIME			
24-HOUR NRC NOTIFICATION <input type="checkbox"/> TPH REGION III DATE TIME <input type="checkbox"/> TGM REGION III & DOL DATE TIME		PROMPT OFF-SITE NOTIFICATION F. A. Palmer 6/22/81 10:25 TITLE DATE TIME TITLE DATE TIME TITLE DATE TIME			
RESPONSIBLE COMPANY OFFICER INFORMED OF 10CFR21 CONDITIONS AND THEIR REPORT TO NRC		Michael Wright 6/22/81 OPERATING ENGINEER DATE			

ACCEPTANCE BY STATION REVIEW
AS REQUIRED

DATE

RESOLUTION APPROVED AND
AUTHORIZED FOR DISTRIBUTION

J. Brunner 7/16/81
Michael Wright 7-16-81
Douglas Costa 7/16/81
 STATION SUPERINTENDENT DATE