NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01	LICENSEE CODE: N Y J A F 1 (2)	LICENSE NUMBER: 0 0 - 0 0 0 0 - 0 0 0 (3)	LICENSE TYPE: 4 1 1 1 1 (4)	CAT: (5)

CON'T

01	REPORT SOURCE: L (6)	DOCKET NUMBER: 0 5 0 0 0 3 3 3 (7)	EVENT DATE: 0 6 2 5 8 1 (8)	REPORT DATE: 0 7 1 0 8 1 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During normal operation, as a result of management review, it was found that
03 both the Electric and Diesel Fire pump flow and pressure tests required by
04 Technical Specifications 4.12.A.1.3.3 were not conducted within the required
05 time period. The tests had exceeded the maximum allowed interval by approximately
06 three weeks. No significant hazard existed.
07
08

09	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
	A B (11)	A (12)	A (13)	Z Z Z Z Z Z (14)	Z (15)	Z (16)

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
8 1	—	0 5 3	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
X (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	Z (25)	Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Failure to place the surveillance tests for the electric and diesel fire pumps
11 on the schedule was the cause. The required tests were performed with satisfactory
12 results the next day and both tests have beed added to the regular surveillance
13 schedule. No additional action is required.
14

15	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
	E (28)	0 9 9 (29)	NA	A (31)	Management Review

16	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
	Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

17	NUMBER	TYPE	DESCRIPTION (39)
	0 0 0 (37)	Z (38)	NA

PERSONNEL INJURIES

18	NUMBER	DESCRIPTION (41)
	0 0 0 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

19	TYPE	DESCRIPTION
	Z (42)	NA

8107240258 810710
PDR ADOCK 05000333
S PDR

PUBLICITY

20	ISSUED	DESCRIPTION (45)
	N (44)	NA

NRC USE ONLY

NAME OF PREPARER W. Verne Childs PHONE: 315-342-3840

GPO 917-926