

CONTROL BLOCK:

--	--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	D	C	C	N	2	0	0	-	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5		
0	1	LICENSEE CODE					14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT 58	

CON'T

0	1	REPORT SOURCE		L	6	0	5	0	0	0	3	1	8	7	0	7	0	4	8	1	8	0	7	1	5	8	1	9		
7	9			60	61	DOCKET NUMBER										68	69	EVENT DATE					74	75	REPORT DATE					80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | At 1420 while paralleling the main turbine generator, pressurizer level

0 3 | deviated from the program level by more than +/- 5% for 30 minutes

0 4 | (T.S. 3.4.4). LER 50-317/81-40 describes a similar event.

0 5 |

0 6 |

0 7 |

0 8 |

09		SYSTEM CODE C B 11		CAUSE CODE X 12		CAUSE SUBCODE Z 13		COMPONENT CODE Z Z Z Z Z 14		COMP. SUBCODE Z 15		VALVE SUBCODE Z 16	
7 8		9 10		11 12		13 14		15 16		17 18		19 20	
17		EVENT YEAR 8 1 21 22		SEQUENTIAL REPORT NO. C 3 3 24 25 26		OCCURRENCE CODE 0 3 28 29		REPORT TYPE L 30 31		REVISION NO. 0 32			
ACTION TAKEN Z 18 33		FUTURE ACTION Z 19 34		EFFECT ON PLANT Z 20 35		SHUTDOWN METHOD Z 21 36		HOURS 0 0 0 0 22 37 38 39 40		ATTACHMENT S. MITT N 23 41		NPRD-4 FORM SUB. N 24 42	
PRIME COMP. SUPPLIER Z 25 43		COMPONENT MANUFACTURER Z 9 9 9 26 44 45 46 47											

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 RCS temperature swings of 10 degrees are not uncommon when paralleling
1 1 the main generator. These temperature swings can result in deviations
1 2 greater than +/- 5% from pressurizer program level. No corrective
1 3 action was deemed necessary.
1 4

FACILITY STATUS (1) 5 (C) (28) % POWER (0) 2 (0) (29) OTHER STATUS (30) NA METHOD OF DISCOVERY (A) (31) Operator Observation DISCOVERY DESCRIPTION (32)
 ACTIVITY CONTENT RELEASED OF RELEASE (1) 6 (Z) (33) (Z) (34) AMOUNT OF ACTIVITY (35) NA LOCATION OF RELEASE (36)
 PERSONNEL EXPOSURES NUMBER (1) 7 (0) 0 0 (37) TYPE (Z) (38) DESCRIPTION (39) NA
 PERSONNEL INJURIES NUMBER (1) 8 (0) 0 0 (40) DESCRIPTION (41) NA
 LOSS OF OR DAMAGE TO FACILITY TYPE (1) 9 (Z) (42) DESCRIPTION (43) NA
 PUBLICITY ISSUED (2) 0 (N) (44) DESCRIPTION (45) NA
 8107240325 810715
 PDR ADOCK C5000318
 S PDR
 NRC USE ONLY

NAME OF PREPARER M. A. Junge

PHONE: (301) 269-4969