

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

at Dresden.

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

verified. The switches will be tested quarterly per DIS 300-1.

NAME OF PREPARED:

PHONE

942-2920 Ext. 489



Commonwealth Edison

DEVIATION REPORT

DVR NO.	STA	UNIT	YEAR	NO.
D-12-3-81-33				

PART 1 TITLE OF DEVIATION

Unit 3 Scram Air System Header Pressure Switch Below Limits

OCCURRED	DATE	TIME
6/16/81	6/16/81	1700

SYSTEM AFFECTED 300

PLANT CONDITIONS

Control Rod Drive

MODE Run

PWR(MWT) 2440.06

LOAD(MWE) 788.29

TESTING	YES	NO
	<input checked="" type="checkbox"/>	<input type="checkbox"/>

DESCRIPTION OF EVENT

While doing Scram Air System Header Pressure Switch Calibration, SOP 8-15-58, found PS-3-302-99A

to trip (contacts close) at 47 psig decreasing and PS 3-302-99B to trip (contacts close) at

49 psig decreasing. Setpoint should be greater than 50 + 2 psig decreasing.

DESCRIPTION OF CAUSE

OTHER APPLICABLE INFORMATION

Pressure switches are reset to trip at 53 psig decreasing and reset at 54.5 psig increasing.

Repeatability was verified.

EQUIPMENT	YES
FAILURE	<input checked="" type="checkbox"/> NO

DR NO.

N/A

WR NO.

N/A

A. R. Zapotocky

RESPONSIBLE SUPERVISOR

6/17/81

DATE

PART 2 OPERATING ENGINEERS COMMENTS

The pressure switches were immediately reset and tested to verify repeatability.

TYPE OF DEVIATION
REPORTABLE OCCURRENCE
☐ 14 DAY ☐ 10CFR21

☒ 30 DAY NOTIFICATION
6.6.B.2.a
EVENT OF POTENTIAL
PUBLIC INTEREST☐TECH SPEC
VIOLATION☐NON-REPORTABLE
OCCURRENCE☐ANNUAL
REPORTINGYES ☒NO ☐SAFETY-
RELATED
WR ISSUEDYES ☐NO ☒REPORTABLE OCCURRENCE
NUMBER

XXX- 81-14/03L-0

ACTION ITEM NO.

PROMPT ON-SITE NOTIFICATION

R. M. Ragan

6/18/81

1300

TITLE

DATE

TIME

TITLE

DATE

TIME

24-HOUR NRC NOTIFICATION

☒ TPH T. Tongue 6/18/81 1000

REGION III

DATE

TIME

☐ TGM

REGION III & DOL

DATE

TIME

PROMPT OFF-SITE NOTIFICATION

F. Palmer

6/18/81

1445

TITLE

DATE

TIME

TITLE

DATE

TIME

RESPONSIBLE COMPANY OFFICER INFORMED OF 10CFR21
CONDITIONS AND THEIR REPORT TO NRC

TITLE

DATE

TIME

REVIEW AND COMPLETED

Michael J. Wright

OPERATING ENGINEER

6/18/81

DATE

ACCEPTANCE BY STATION REVIEW
AS REQUIRED

DATE

RESOLUTION APPROVED AND
AUTHORIZED FOR DISTRIBUTIONJ. R. Ciesla
7-15-81Michael Wright
7-15-81
STATION SUPERINTENDENT7/15/81
DATE