



ARKANSAS POWER & LIGHT COMPANY

POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 271-4000

July 9, 1981

2CANØ781Ø5

Mr. G. L. Madsen, Chief
Reactor Operations & Nuclear Support
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011



Subject: Arkansas Nuclear One - Unit 2
Docket No. 50-368
License No. NPF-6
Licensee Event Report No. 81-022/03L-0
(File: 2-0520)

Gentlemen:

In accordance with Arkansas Nuclear One - Unit 2 Technical Specification 6.9.1.9.b, attached is the subject report concerning radiation monitor 2RITS-8750-1 trip setpoint value found to be greater than 2 times above normal background radiation.

Very truly yours,

David C. Trimble

David C. Trimble
Manager, Licensing

DCT:GAC:lfw

Attachment

cc: Mr. Victor Stello, Jr., Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. Norman M. Haller, Director
Office of Management & Program Analysis
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

IE22
3
111

8107280178 810709
PDR ADDCK 05000368
S PDR