NRC FORM 366
(7 77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | ARANO2 (2) | 00-000-00 (3) | 4 | 1111 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 050003 68 (7) | 061081 (8) | 070981 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | Control room ventilation radiation monitor 2RITS 8750-1 trip setpoint was
03 | found to be >2 times background radiation. Trip setpoint was set at 500
04 | to 1000 cpm. This condition could result in a high radiation environment
05 | without proper early warning to allow mitigation of the condition. This
06 | is reportable per Tech. Spec. 6.9.1.9.b.
07 |
08 |

09 | SYSTEM CODE MC (11) | CAUSE CODE 0 (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE ZZZZZZ (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 81 | — | SEQUENTIAL REPORT NO. 022 | — | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO 0

ACTION TAKEN G (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB N (24) | PRIME COMP. SUPPLIER Z (25) | COMPONENT MANUFACTURER Z999 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | High alarm setpoint was set as required by quarterly procedure 2304.26
11 | with the value listed on the front of the drawer. This value is listed
12 | erroneously as 5000 cpm. The correct value should be ≤2 times background
13 | radiation. High alarm setpoint was changed to ≈ 3000 cpm and the posted
14 | value was changed. Procedure will be modified to periodically determine background level and update posted values.

15 | FACILITY STATUS H (28) | % POWER 000 (29) | OTHER STATUS N/A (30) | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Observation

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 | PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 | PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) NA

19 | LOSS OF OR DAMAGE TO FACILITY (43) TYPE Z (42) | DESCRIPTION NA

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

NAME OF PREPARER Ken Morton PHONE: 501/968-2519

8107280182 810709
PDR ADOCK 05000368
S PDR