

PACIFIC GAS AND ELECTRIC COMPANY

PG&E

P. O. BOX 7442 • 77 BEALE STREET, 31ST FLOOR, SAN FRANCISCO, CALIFORNIA 94106
TELEPHONE (415) 781-4211 TELECOPIER (415) 543-7813

ROBERT OHLBACH
VICE PRESIDENT AND GENERAL ATTORNEY

CHARLES T. VAN DEUSEN
PHILIP A. CRANE, JR.
HENRY J. LAPLANTE
JOHN B. GIBSON
ARTHUR L. HILLMAN, JR.
CHARLES W. THIBSELL
DANIEL E. GIBSON
JACK F. FALLIN, JR.
JOSEPH J. KELLY
ASSISTANT GENERAL COUNSEL

July 14, 1981

DANIEL L. HARRIS
DEEN WEST, JR.
HOWARD V. SOULS
JAMES C. LORSON
ROBERT L. BORDON
PETER W. HANCOCK
RICHARD F. LOCKE
DAVID L. LUDWIGSON
WILLIAM H. EDWARDS
F. RONALD LAUFHEIMER
ROBERT W. RICKERT
DAVID J. WILLIAMS
BRUCE R. WORTHINGTON

EDWARD J. MCDANNEY
DAK GRAYSON LURBECK
BERNARD J. DELLASANTA
JOSHUA BARLEY
JOSEPH B. ENSLERT, JR.
ROBERT L. HARRIS
DOUGLAS A. DOLESBY
J. PETER BAUMGARTNER
JOHN N. FRYE
J. MICHAEL REIDENBACH
LYON E. BARNES
BARLEY A. WOOD

SENIOR COUNSEL

DAVID W. ANDERSON
DIANA BERGMAN
LEIGH S. CASSIDY
ALBERT DAVIS
DONALD D. ERICKSON
PATRICK D. GOLDEN
PAULA T. JONES
RICHARD L. JONES
HARRY W. LONG, JR.
JOHN E. LOW
ROBERT B. MULENAN
RICHARD H. MOSS
SHIRLEY A. SANDERSON
JACK W. SHUCK
KENNETH YARD

ATHAN T. ANHARD
STEVEN P. BURKE
PAMELA CHAPPELLE
DARY P. ENGLISH
DAVID C. GILBERT
STEVEN F. GREENWALD
JUAN M. JATO
MERCK E. LIPSON
JESSICA LORING
A. KIM MCKENZIE
RICHARD L. MEISS
ROGER J. PETERS
JO ANN SHAFER
LOUIS E. VINCENT

ATTORNEYS

Mr. R. H. Engelken, Director
Office of Inspection and Enforcement
Region V
U. S. Nuclear Regulatory Commission
1990 N. California Boulevard
Walnut Creek Plaza, Suite 202
Walnut Creek, CA 94596

Re: Docket No. 50-275
Docket No. 50-323
Diablo Canyon Units 1 and 2

Dear Mr. Engelken:

The following is submitted in reply to the request in your letter dated June 19, 1981 regarding specific information concerning the Emergency Notification System:

Item 1 Access for telephone company representatives for survey and installations.

Access to Diablo Canyon Power Plant is obtained through Plant Security. Contact Mr. Robert R. Smith, on site, at (805) 595-7351 for clearance.

Item 2 Power for station packages.

PGandE has provided Pacific Telephone with access to its 48 Volt D.C. telecommunications battery power for all



IEH
5/10

July 14, 1981

critical circuits and equipment. We recommend that the new ENS equipment proposed at the power plant site be configured for 48 Volt D.C. operation.

Item 3 Adequate cable facilities.

The existing ENS circuit is served from a 4-wire lease and telephone sets which are in place within the power plant. Based on a review of the material attached to your letter, additional cable facilities do not appear to be required. In the event additional pairs are required, we will arrange to provide cable as needed.

Item 4 Telecommunications planning personnel.

Either of the following two individuals on the Company's Communications Department's Staff can be contacted for required support and assistance:

Mr. August J. Nevolo (415) 541-5516
Mr. Albert M. Badella (415) 781-4211, ext. 3579

Item 5 A list of ENS station locations.

The ENS station locations are as follows:

DIABLO CANYON POWER PLANT SITE (Existing)

- 1) PGandE Control Room
- 2) PGandE Shift Foreman's Office, Auxiliary Building
- 3) NRC - Power Plant Office, Trailer - on site
- 4) NRC - TSC Office, Buttress Cubicle - Unit 2

July 14, 1981

OFF SITE LOCATIONS

- 1) PGandE Information Center (Back up EOF), Highway 101 (Existing)
- 2) NRC Office - County Emergency Operations Center (EOC), San Luis Obispo County Sheriff's facility, San Luis Obispo, California (Proposed)

Item 6 Planned station moves or installations to be completed.

None, other than the installation at the EOC.

Item 7 Temporary ENS station locations.

None.

Item 8 Anticipated problems in meeting a system upgrade start date of 8/1/81.

No problems anticipated.

Sincerely,

Philip A. Graw

CC: F. J. Miraglia, Jr., Chief
Dan Sternberg
NRC Regional Project Officer