



**Commonwealth Edison**

Quad Cities Nuclear Power Station  
22710 206 Avenue North  
Cordova, Illinois 61242  
Telephone 309/654-2241

*DMB/LER*

NJK-81-240

July 10, 1981



J. Keppler, Regional Director  
Office of Inspection and Enforcement  
Region III  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Reference: Quad-Cities Nuclear Power Station  
Docket Number 50-254, DPR-29, Unit One  
Appendix A, Section 6.6.B.2.a, Table 3.1-3

Enclosed please find Reportable Occurrence Report Number RO 81-12/03L-0  
for Quad-Cities Nuclear Power Station.

This report is submitted to you in accordance with the requirements of  
Technical Specification 6.6.B.2.a, as a reactor protection system  
feature instrument setting found to be less conservative than that  
established by Technical Specifications but which would not prevent  
the fulfillment of the functional requirements of affected systems.

Very truly yours,

COMMONWEALTH EDISON COMPANY  
QUAD-CITIES NUCLEAR POWER STATION

*L. J. Mermer for*  
N. J. Kalivianakis  
Station Superintendent

NJK:JJK/bb

Enclosure

cc T. Rausch  
N. Chrissotimos

*IE22  
8/11*

8107280308 810710  
PDR ADOCK 05000254  
S PDR

JUL 22 1981