

SUNSI Review Complete
 Template = ADM-013
 E-RIDS=ADM-03
 ADD: Mark Notich

As of: 1/8/20 8:08 AM
Received: December 30, 2019
Status: Pending_Post
Tracking No. 1k3-9e5w-vwbc
Comments Due: January 13, 2020
Submission Type: Web

PUBLIC SUBMISSION

COMMENT (1)
 PUBLICATION DATE:
 11/12/2019
 CITATION 84 FR 61082

Docket: NRC-2019-0177

Proposed Revisions to Draft Branch Technical Position 8-8, Onsite and Offsite Power Sources Completion Time Extensions

Comment On: NRC-2019-0177-0001

Proposed Revisions to Draft Branch Technical Position 8-8 Onsite (Emergency Diesel Generators) and Offsite Power Sources Completion Time Extensions; Request for Comment on Draft Section of Standard Review Plan

Document: NRC-2019-0177-DRAFT-0002

Comment on FR Doc # 2019-24551

Submitter Information

Name: Jaak Saame

Address:

10950 Minnesota Avenue
 Penngrove, CA, 94951

Email: jaak1943@sonic.net

General Comment

Draft BTP says:

On a case-by-case basis, the staff may consider licensee requests for a reasonable amount of time if needed beyond 14-days to support sufficient time for the licensee to complete the EDG overhauls or repairs, if supported by risk information.

Comment:

If EDG overhauls or repairs require more than 14 days, then the plant must be brought to a cold shutdown position. It is too dangerous to continue power operation without EDG.