CONTROL BLOCK: _____ (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

F L 2 0 2 3 0 - 0 0 0 - 0 0 - 0 0 - 0 0 - 4 (4) L (5)

LICENSEE CODE (6) | LICENSE NUMBER (7) | LICENSE TYPE (8) | CON'T (9)

SOURCE (10) | DOCKET NUMBER (11) | EVENT DATE (12) | REPORT DATE (13)

0 5 0 0 0 3 0 2 | 0 6 1 7 8 1 | 0 7 1 4 8 1

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (14)

At 1536 during hot shutdown operation, a lightning strike rendered all meteorological instrumentation inoperable. This created an event contrary to T.S 3.3.3.4. Maintenance was initiated. Operability was restored at 1730 to all but the 175' windspeed instrument. Full operability was restored at 1130 6/24/81. There was no effect upon the health or safety of the general public. This was the first lightning induced loss of all meterological instrumentation and this is the thirteenth event reported under this Specification.

SYSTEM CODE (11)	CAUSE CODE (12)	CAUSE SUBCODE (13)	COMPONENT CODE (14)	COMP SUBCODE (15)	VALVE SUBCODE (16)
I E	C	Z	I N S T R U	X	Z

LER/RO REPORT NUMBER (17)	EVENT YEAR	SEQUENTIAL REPORT NO.	OCCURRENCE CODE	REPORT TYPE	REVISION NO
	8 1	0 3 4	0 3	L	0

ACTION TAKEN (18)	ACTION (19)	EFFECT ON PLANT (20)	SHUTDOWN METHOD (21)	HOURS (22)	ATTACHMENT SUBMITTED (23)	FORM SUBMITTED (24)	SOURCE SUPPLIER (25)	COMPONENT MANUFACTURER (26)
A	X	Z	Z	0 0 0 0	Y	N	A	E 0 7 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

The cause of this event is attributed to lightning striking the meteorological instrumentation. All affected instrumentation was repaired or replaced and the functional test was satisfactory. An engineering investigation will be conducted to evaluate the installed lightning eliminator system.

STATUS (28)	POWER (29)	OTHER STATUS (30)	METHOD OF DISCOVERY (31)	DISCOVERY DESCRIPTION (32)
G	0 0 0	NA	A	Operator observation

ACTIVITY RELEASED OR RELEASE (33)	CONTENT (34)	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
Z	Z	NA	NA

PERSONNEL EXPOSURES

NUMBER (37)	TYPE (38)	DESCRIPTION (39)
0 0 0	Z	NA

PERSONNEL INJURIES

NUMBER (40)	DESCRIPTION (41)
0 0 0	NA

LOSS OF OR DAMAGE TO FACILITY (42)

TYPE (43)	DESCRIPTION
Z	NA

PUBLICITY (44)

N	DESCRIPTION (45)
	NA

NRC USE ONLY

Name of Preparer: Victor A. Hernandez PHONE: (904) 795-6486

8107280376 810714
PDR ADOCK 05000302
S PDR

ATTACHED SUPPLEMENTARY INFORMATION SHEET